



KENYA ELECTRICITY GENERATING COMPANY LIMITED

KGN-GDD-030-2017

**TENDER FOR SUPPLY OF INSTRUMENT SPARES FOR
OLKARIA POWER PLANTS**

Kenya Electricity Generating Company Limited
Stima Plaza Phase III, Kolobot Road, Parklands
P.O. BOX 47936-00100
NAIROBI.

Website: www.kengen.co.ke

APRIL , 2017

TENDER FOR HIGH PERFORMANCE 180 AMPERE HOUR BATTERIES FOR OLKARIA II POWER STATION

**SECTION I
INVITATION TO TENDER**

The Company invites sealed tenders from eligible candidates for the **Tender for Supply of Instrument Spares for Olkaria Power Plants**, whose specifications are detailed in the Tender Document. Interested eligible candidates may obtain further information from and inspect the Tender Documents during official working hours starting at the date of advert at the office of:

Supply Chain Director
Tel: (254) (020) 3666000
Email: tenders@kengen.co.ke; jgesaka@kengen.co.ke

where the tender document may be collected upon payment of a non-refundable fee of **KShs.1,000.00** paid in cash or through a bankers cheque at any KenGen finance office. The document can also be viewed and downloaded from the website www.kengen.co.ke and www.suppliers.treasury.go.ke. Bidders who download the tender document from the website **are advised to forward their particulars to facilitate any subsequent tender clarifications and addenda**. Downloaded copies are free of charge.

Bidders are advised from time to time to be checking the website for any uploaded further information on this tender. Bidders should be keen on the information provided under the Appendix to Instructions to Tenderers (A.I.T.T.) and the Special conditions of the Contract (S.C.C.). Unless otherwise stated, tenders **MUST** be accompanied by a security in the format and amount specified in the tender documents and must be submitted in a plain sealed envelope and marked **“KGN-GDD-030-2017-Supply of Instrument Spares for Olkaria Power Plants”** and addressed to:

**Company Secretary & Legal Affairs Director
Kenya Electricity Generating Company Limited
10th Floor, KenGen Pension Plaza Phase II
Kolobot Road, Parklands
P O Box 47936 - 00100
NAIROBI, KENYA**

On or before: **11th May 2017 at 2.00PM**. Tenders will be opened on **11th May 2017 at 2.30PM**. in the presence of the candidates’ representatives who choose to attend at Stima Plaza III, Executive Committee Room, 7th Floor. The company reserves the right to vary the quantities.

N/B: KenGen adheres to high standards of integrity in its business operations. Report any unethical behavior immediately to the provided anonymous hotline service.

- 1) Call Toll Free: 0800722626
- 2) FreeFax: 00800 007788
- 3) Email: kengen@tip-offs.com
- 4) Website : www.tip-offs.com

SUPPLY CHAIN DIRECTOR.

SECTION II
INSTRUCTIONS TO TENDERERS
Eligible Tenderers

- 2.1.1 This Invitation for Tenders is open to all tenderers eligible as described in the Invitation to Tender. Successful tenderers shall complete the supply of goods by the intended completion date specified in the Schedule of Requirements (Section VI).
- 2.1.2 The procuring entity's employees, committee members, board members and their relative (spouse and children) are not eligible to participate in the tender.
- 2.1.3 Tenderers shall provide the qualification information statement that the tenderer (including all members of a joint venture and subcontractors) is not associated, or have been associated in the past, directly or indirectly, with a firm or any of its affiliates which have been engaged by the Procuring entity to provide consulting services for the preparation of the design, specifications, and other documents to be used for the procurement of the goods under this Invitation for tenders.
- 2.1.4 Tenderers shall not be under a declaration of ineligibility for corrupt and fraudulent practices.

2.2 Eligible Goods

- 2.2.1 All goods to be supplied under the contract shall have their origin in eligible source countries.
- 2.2.2 For purposes of this clause, "origin" means the place where the goods are mined, grown, or produced. Goods are produced when, through manufacturing, processing, or substantial and major assembly of components, a commercially-recognized product results that is substantially different in basic characteristics or in purpose or utility from its components
- 2.2.3 The origin of goods is distinct from the nationality of the tenderer.

2.3 Cost of Tendering

- 2.3.1 The Tenderer shall bear all costs associated with the preparation and submission of its tender, and the procuring entity, will in no case be responsible or liable for those costs, regardless of the conduct or outcome of the tendering process.

2.3.2 The price to be charged for the tender document collected from the Procuring Entity shall not exceed Kshs.1,000/=. Downloaded copies are free of charge.

2.3.3 All firms found capable of performing the contract satisfactorily in accordance with the set prequalification criteria shall be prequalified.

2.4. The Tender Document

2.4.1 The tender document comprises the documents listed below and addenda issued in accordance with clause 2.6 of these instructions to Tenderers

- (i) Invitation to Tender
- (ii) Instructions to tenderers
- (iii) General Conditions of Contract
- (iv) Special Conditions of Contract
- (v) Schedule of requirements
- (vi) Technical Specifications
- (vii) Tender Form and Price Schedules
- (viii) Tender Security Form
- (ix) Contract Form
- (x) Performance Security Form
- (xi) Manufacturer's Authorization Form
- (xii) Confidential Business Questionnaire

2.4.2 The Tenderer is expected to examine all instructions, forms, terms, and specifications in the tender documents. Failure to furnish all information required by the tender documents or to submit a tender not substantially responsive to the tender documents in every respect will be at the tenderers risk and may result in the rejection of its tender.

2.5 Clarification of Documents

2.5.1 A prospective tenderer requiring any clarification of the tender document may notify the Procuring entity in writing or by post at the entity's address indicated in the Invitation to Tender. The Procuring entity will respond in writing to any request for clarification of the tender documents, which it receives not later than **seven (7) days prior to the deadline for the submission of tenders**, prescribed by the procuring entity. Written copies of the Procuring entities response (including an explanation of the query but without identifying the source of inquiry) will be sent to all prospective tenderers that have received the tender document.

2.5.2 The procuring entity shall reply to any clarifications sought by the tenderer **within 3 days** of receiving the request to enable the tenderer to make timely submission of its tender.

2.6 **Amendment of Documents**

2.6.1 **At any time prior** to the deadline for submission of tenders, the Procuring entity, for any reason, whether at its own initiative or in response to a clarification requested by a prospective tenderer, may modify the tender documents by amendment.

2.6.2 All prospective candidates that have received the tender documents will be notified of the amendment in email and will be binding on them.

2.6.3 In order to allow prospective tenderers reasonable time in which to take the amendment into account in preparing their tenders, the Procuring entity, at its discretion, may extend the deadline for the submission of tenders.

2.7 **Language of Tender**

2.7.1 The tender prepared by the tenderer, as well as all correspondence and documents relating to the tender exchange by the tenderer and the Procuring entity, shall be written in English language, provided that any printed literature furnished by the tenderer may be written in another language provided they are accompanied by an accurate English translation of the relevant passages in which case, for purposes of interpretation of the tender, the English translation shall govern.

2.8 **Documents Comprising of Tender**

2.8.1 The tender prepared by the tenderers shall comprise the following components:

- (a) a Tender Form and a Price Schedule completed in accordance with paragraph 2.9, 2.10 and 2.11 below
- (b) documentary evidence established in accordance with paragraph 2.1 that the tenderer is eligible to tender and is qualified to perform the contract if its tender is accepted;
- (c) documentary evidence established in accordance with paragraph 2.2 that the goods and ancillary services to be supplied by the tenderer are eligible goods and services and conform to the tender documents; and
- (d) tender security furnished in accordance with paragraph 2.14.

2.9 **Tender Forms**

2.9.1 The tenderer shall complete the Tender Form and the appropriate Price Schedule furnished in the tender documents, indicating the goods to be supplied, a brief description of the goods, their country of origin, quantity, and prices.

2.10 **Tender Prices**

2.10.1 The tenderer shall indicate on the appropriate Price Schedule the unit prices and total tender price of the goods it proposes to supply under the contract

2.10.2 Prices indicated on the Price Schedule shall include all costs including taxes, insurances and delivery to the premises of the entity.

2.10.3 Prices quoted by the tenderer shall be fixed during the Tender's performance of the contract and not subject to variation on any account. A tender submitted with an adjustable price quotation will be treated as non-responsive and will be rejected, pursuant to paragraph 2.22

2.10.4 The validity period of the tender shall be **90 days from** the date of opening of the tender.

2.11 **Tender Currencies**

2.11.1 Prices shall be quoted in Kenya Shillings unless otherwise specified in the Appendix to Instructions to Tenderers.

2.12 **Tenderers Eligibility and Qualifications**

2.12.1 Pursuant to paragraph 2.1. the tenderer shall furnish, as part of its Tender, documents establishing the tenderers eligibility to tender and Its qualifications to perform the contract if its tender is accepted.

2.12.2 The documentary evidence of the tenderers eligibility to tender shall establish to the Procuring entity's satisfaction that the tenderer, at the time of submission of its tender, is from an eligible source country as defined under paragraph 2.1

2.12.3 The documentary evidence of the tenderers qualifications to perform the contract if its tender is accepted shall be established to the Procuring entity's satisfaction;

- (a) that, in the case of a tenderer offering to supply goods under the contract which the tenderer did not manufacture or otherwise

produce, the tenderer has been duly authorized by the goods' Manufacturer or producer to supply the goods.

- (b) that the tenderer has the financial, technical, and production capability necessary to perform the contract;
- (c) that, in the case of a tenderer not doing business within Kenya, the tenderer is or will be (if awarded the contract) represented by an Agent in Kenya equipped, and able to carry out the Tenderer's maintenance, repair, and spare parts-stocking obligations prescribed in the Conditions of Contract and/or Technical Specifications.

2.13 Goods Eligibility and Conformity to Tender Documents

2.13.1 Pursuant to paragraph 2.2 of this section, the tenderer shall furnish, as part of its tender documents establishing the eligibility and conformity to the tender documents of all goods which the tenderer proposes to supply under the contract

2.13.2 The documentary evidence of the eligibility of the goods shall consist of a statement in the Price Schedule of the country of origin of the goods and services offered which shall be confirmed by a certificate of origin issued at the time of shipment.

2.13.3 The documentary evidence of conformity of the goods to the tender documents may be in the form of literature, drawings, and data, and shall consist of:

- (a) a detailed description of the essential technical and performance characteristic of the goods;
- (b) a list giving full particulars, including available source and current prices of spare parts, special tools, etc., necessary for the proper and continuing functioning of the goods for a period of two (2) years, following commencement of the use of the goods by the Procuring entity (*if applicable*); and
- (c) a clause-by-clause commentary on the Procuring entity's Technical Specifications demonstrating substantial responsiveness of the goods and service to those specifications, or a statement of deviations and exceptions to the provisions of the Technical Specifications.

2.13.4 For purposes of the documentary evidence to be furnished pursuant to paragraph 2.13.3(c) above, the tenderer shall note that standards for workmanship, material, and equipment, as well as references to brand names or catalogue numbers designated by the Procurement entity in its Technical Specifications, are intended to be descriptive only and not restrictive. The tenderer may substitute alternative standards, brand names,

and/or catalogue numbers in its tender, provided that it demonstrates to the Procurement entity's satisfaction that the substitutions ensure substantial equivalence to those designated in the Technical Specifications.

2.14 Tender Security

2.14.1 The tenderer shall furnish, as part of its tender, a tender security for the amount specified in the Appendix to Invitation to Tenderers.

2.14.2 The tender security shall be in the amount of *(Specify the amount)*.

2.14.3 The tender security is required to protect the Procuring entity against the risk of Tenderer's conduct which would warrant the security's forfeiture, pursuant to paragraph 2.14.7

2.14.4 The tender security shall be denominated in Kenya Shillings or in another freely convertible currency, and shall be in the form of an on-demand bank guarantee issued by a reputable bank located in Kenya or where the bank is located abroad, it must have a local correspondent bank.

The Tender Security may also be in the form of an on-demand guarantee issued by a reputable insurance company approved by the Authority and in the form provided in the tender documents or another form acceptable to the Procuring entity.

The tender security must be valid for at least thirty (30) days beyond the validity of the tender.

2.14.5 Any tender not secured in accordance with paragraph 2.14.1 and 2.14.3 will be rejected by the Procuring entity as non responsive, pursuant to paragraph 2.22

2.14.6 Unsuccessful Tenderer's tender security will be discharged or returned as promptly as possible, but not later than thirty (30) days after the expiration of the period of tender validity prescribed by the Procuring entity.

2.14.7 The successful Tenderer's tender security will be discharged upon the tenderer signing the contract, pursuant to paragraph 2.27 and furnishing the performance security, pursuant to paragraph 2.28

2.14.8 The tender security may be forfeited:

- (a) if a tenderer withdraws its tender during the period of tender validity specified by the procuring entity on the Tender Form; or
- (b) in the case of a successful tenderer, if the tenderer fails:

- (i) to sign the contract in accordance with paragraph 2.27
- or
- (ii) to furnish performance security in accordance with paragraph 2.28

2.15 Validity of Tenders

2.15.1 Tenders shall remain valid for **90 days from** the date of tender opening prescribed by the Procuring entity, pursuant to paragraph 2.18. A tender valid for a shorter period shall be rejected by the Procuring entity as non responsive.

2.15.2 In exceptional circumstances, the Procuring entity may solicit the Tenderer's consent to an extension of the period of validity. The request and the responses thereto shall be made in writing. The tender security provided under paragraph 2.14 shall also be suitably extended. A tenderer may refuse the request without forfeiting its tender security. A tenderer granting the request will not be required nor permitted to modify its tender.

2.16 Format and Signing of Tender

2.16.1 The Tenderer shall prepare **two copies of the tender**, clearly marking each "ORIGINAL TENDER" and "COPY OF TENDER," as appropriate. In the event of any discrepancy between them, the original shall govern.

2.16.2 The original and all copies of the tender shall be typed or written in indelible ink and shall be signed by the tenderer or a person or persons duly authorized to bind the tenderer to the contract. **The latter authorization shall be indicated by written power-of-attorney accompanying the tender. All pages of the tender, except for un-amended printed literature, shall be initialed by the person or persons signing the tender.**

2.16.3 The tender shall have no interlineations, erasures, or overwriting except as necessary to correct errors made by the tenderer, in which case such corrections shall be initialed by the person or persons signing the tender.

2.17 Sealing and Marking of Tenders

2.17.1 The Tenderer shall seal the original and each copy of the tender in separate envelopes, duly marking the envelopes as "ORIGINAL" and "COPY." The envelopes shall then be sealed in an outer envelope.

2.17.2 The inner and outer envelopes shall:

(a) be addressed to the Procuring entity at the address given in the Invitation to Tender:

(b) bear, tender number and name in the Invitation for Tenders and the words, “DO NOT OPEN BEFORE, **11th May 2017 at 2.00PM.**”

2.17.3 The inner envelopes shall also indicate the name and address of the tenderer to enable the tender to be returned unopened in case it is declared “late”.

2.17.4 If the outer envelope is not sealed and marked as required by paragraph 2.17.2, the Procuring entity will assume no responsibility for the tender’s misplacement or premature opening.

2.18 Deadline for Submission of Tenders

2.18.1 Tenders must be received by the Procuring entity at the address specified under paragraph 2.17.2 no later than **11th May 2017 at 2.00PM.**

2.18.2 The Procuring entity may, at its discretion, extend this deadline for the submission of tenders by amending the tender documents in accordance with paragraph 2.6, in which case all rights and obligations of the Procuring entity and candidates previously subject to the deadline will therefore be subject to the deadline as extended

2.19 Modification and Withdrawal of Tenders

2.19.1 The tenderer may modify or withdraw its tender after the tender’s submission, provided that written notice of the modification, including substitution or withdrawal of the tenders, is received by the Procuring Entity prior to the deadline prescribed for submission of tenders.

2.19.2 The Tenderer’s modification or withdrawal notice shall be prepared, sealed, marked, and dispatched in accordance with the provisions of paragraph 2.17. A withdrawal notice may also be sent by cable, telex but followed by a signed confirmation copy, postmarked not later than the deadline for submission of tenders.

2.19.3 No tender may be modified after the deadline for submission of tenders.

2.19.4 No tender may be withdrawn in the interval between the deadline for submission of tenders and the expiration of the period of tender validity specified by the tenderer on the Tender Form. Withdrawal of a tender during this interval may result in the Tenderer’s forfeiture of its tender security, pursuant to paragraph 2.14.7

2.19.5 The procuring entity may at any time terminate procurement proceedings before contract award and shall not be liable to any person for the termination.

2.19.6 The procuring entity shall give prompt notice of the termination to the tenderers and on request give its reasons for termination within 14 days of receiving the request from any tenderer.

2.20 Opening of Tenders

2.20.1 The Procuring entity will open all tenders in the presence of tenderers' representatives who choose to attend, at **11th May 2017 at 2.30PM**, and in the location specified in the Invitation to Tender.

The tenderers' representatives who are present shall sign a register evidencing their attendance.

2.20.2 The tenderers' names, tender modifications or withdrawals, tender prices, discounts and the presence or absence of requisite tender security and such other details as the Procuring entity, at its discretion, may consider appropriate, will be announced at the opening.

2.20.3 The Procuring entity will prepare minutes of the tender opening.

2.21 Clarification of Tenders

2.21.1 To assist in the examination, evaluation and comparison of tenders the Procuring entity may, at its discretion, ask the tenderer for a clarification of its tender. The request for clarification and the response shall be in writing, and no change in the prices or substance of the tender shall be sought, offered, or permitted.

2.21.2 Any effort by the tenderer to influence the Procuring entity in the Procuring entity's tender evaluation, tender comparison or contract award decisions may result in the rejection of the tenderers' tender.

2.22 Preliminary Examination

2.22.1 The Procuring entity will examine the tenders to determine whether they are complete, whether any computational errors have been made, whether required sureties have been furnished, whether the documents have been properly signed, and whether the tenders are generally in order.

2.22.2 Arithmetical errors will be rectified on the following basis. If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantify, the unit price shall prevail, and the total price shall be corrected. If the candidate does not accept the correction of the errors, its tender will be rejected, and its tender security forfeited. If there is a discrepancy between words and figures the amount in words will prevail

2.22.3 The Procuring entity may waive any minor informality or non-conformity or irregularity in a tender which does not constitute a material deviation, provided such waiver does not prejudice or affect the relative ranking of any tenderer.

2.22.4 Prior to the detailed evaluation, pursuant to paragraph 2.23 the Procuring entity will determine the substantial responsiveness of each tender to the tender documents. For purposes of these paragraphs, a substantially responsive tender is one, which conforms to all the terms and conditions of the tender documents without material deviations. The Procuring entity's determination of a tender's responsiveness is to be based on the contents of the tender itself without recourse to extrinsic evidence.

2.22.5 If a tender is not substantially responsive, it will be rejected by the Procuring entity and may not subsequently be made responsive by the tenderer by correction of the non conformity.

2.23 Conversion to Single Currency

2.23.1 Where other currencies are used, the procuring entity will convert these currencies to Kenya Shillings using the selling exchange rate on the date of tender closing provided by the Central Bank of Kenya.

2.24 Evaluation and Comparison of Tenders

2.24.1 The Procuring entity will evaluate and compare the tenders which have been determined to be substantially responsive, pursuant to paragraph 2.22

2.24.2 The tender evaluation committee shall evaluate the tender within 30 days of the validity period from the date of opening the tender.

2.24.3 A tenderer who gives false information in the tender document about its qualification or who refuses to enter into a contract after notification of contract award shall be considered for debarment from participating in future public procurement.

2.25 Preference

2.25.1 Preference where allowed in the evaluation of tenders shall not exceed 15%

2.26 Contacting the Procuring entity

2.26.1 Subject to paragraph 2.21 no tenderer shall contact the Procuring entity on any matter related to its tender, from the time of the tender opening to the time the contract is awarded.

2.26.2 Any effort by a tenderer to influence the Procuring entity in its decisions on tender, evaluation, tender comparison, or contract award may result in the rejection of the Tenderer's tender.

2.27 Award of Contract

(a) Post-qualification

2.27.1 In the absence of pre-qualification, the Procuring entity will determine to its satisfaction whether the tenderer that is selected as having submitted the lowest evaluated responsive tender is qualified to perform the contract satisfactorily.

2.27.2 The determination will take into account the tenderer financial, technical, and production capabilities. It will be based upon an examination of the documentary evidence of the tenderers qualifications submitted by the tenderer, pursuant to paragraph 2.12.3 as well as such other information as the Procuring entity deems necessary and appropriate.

2.27.3 A positive determination will be a prerequisite for award of the contract to the tenderer. A negative determination will result in rejection of the Tenderer's tender, in which event the Procuring entity will proceed to the next lowest evaluated tender to make a similar determination of that Tenderer's capabilities to perform satisfactorily.

(b) Award Criteria

2.27.4 The Procuring entity will award the contract to the successful tenderer(s) whose tender has been determined to be substantially responsive and has been determined to be the lowest evaluated tender, provided further that the tenderer is determined to be qualified to perform the contract satisfactorily.

(c) **Procuring entity's Right to Vary quantities**

2.27.5 The Procuring entity reserves the right at the time of contract award to increase or decrease the quantity of goods originally specified in the Schedule of requirements without any change in unit price or other terms and conditions

(d) **Procuring entity's Right to accept or Reject any or All Tenders**

2.27.6 The Procuring entity reserves the right to accept or reject any tender, and to annul the tendering process and reject all tenders at any time prior to contract award, without thereby incurring any liability to the affected tenderer or tenderers or any obligation to inform the affected tenderer or tenderers of the grounds for the Procuring entity's action

2.28 Notification of Award

2.28.1 Prior to the expiration of the period of tender validity, the Procuring entity will notify the successful tenderer in writing that its tender has been accepted.

2.28.2 The notification of award will constitute the formation of the Contract but will have to wait until the contract is finally signed by both parties.

2.28.3 Upon the successful Tenderer's furnishing of the performance security pursuant to paragraph 2.28, the Procuring entity will promptly notify each unsuccessful Tenderer and will discharge its tender security, pursuant to paragraph 2.14.

2.29 Signing of Contract

2.29.1 At the same time as the Procuring entity notifies the successful tenderer that its tender has been accepted, the Procuring entity will send the tenderer the Contract Form provided in the tender documents, incorporating all agreements between the parties.

2.29.2 The parties to the contract shall have it signed within **fifteen (15) days** from the date of notification of contract award unless there is an administrative review request.

2.29.3 Within **fifteen (15) days** of receipt of the Contract Form, the successful tenderer shall sign and date the contract and return it to the Procuring entity.

2.30 Performance Security

2.30.1 Within **fifteen (15) days** of the receipt of notification of award from the Procuring entity, the successful tenderer shall furnish the performance security in accordance with the Conditions of Contract, in the Performance Security Form provided in the tender documents, or in another form acceptable to the Procuring entity.

2.30.2 Failure of the successful tenderer to comply with the requirements of paragraph 2.27 or paragraph 2.28 shall constitute sufficient grounds for the annulment of the award and forfeiture of the tender security, in which event the Procuring entity may make the award to the next lowest evaluated Candidate or call for new tenders.

2.31 Corrupt or Fraudulent Practices

2.31.1 The Procuring entity requires that tenderers observe the highest standard of ethics during the procurement process and execution of contracts when used in the present regulations, the following terms are defined as follows;

- (i) “corrupt practice” means the offering, giving, receiving, or soliciting of anything of value to influence the action of a public official in the procurement process or in contract execution; and
- (ii) “fraudulent practice” means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of the Procuring entity, and includes collusive practice among tenderer (prior to or after tender submission) designed to establish tender prices at artificial non-competitive levels and to deprive the Procuring entity of the benefits of free and open competition;

2.31.2 The procuring entity will reject a proposal for award if it determines that the tenderer recommended for award has engaged in corrupt or fraudulent practices in competing for the contract in question.

2.31.3 Further a tenderer who is found to have indulged in corrupt or fraudulent practices risks being debarred from participating in public procurement in Kenya.

Appendix to Instructions to Tenderers

The following information regarding the particulars of the tender shall complement supplement or amend the provisions of the instructions to tenderers. Wherever there is a conflict between the provision of the instructions to tenderers and the provisions of the appendix, the provisions of the appendix herein shall prevail over those of the instructions to tenderers.

INSTRUCTIONS TO TENDERERS REFERENCE	PARTICULARS OF APPENDIX TO INSTRUCTIONS TO TENDERS
2.1.1	This Invitation for Tenders is open to all tenderers eligible as described in the Invitation to Tender.
2.10.4	The validity period of the tender shall be 120 days from the date of opening of the tender
2.14.2	The tender security shall be in the amount of Kenya Shillings Four Hundred Thousand (KShs. 400,000.00) or equivalent in a freely convertible currency.
2.16.1	The Tenderer shall prepare two copies of the tender , clearly marking each “ ORIGINAL TENDER ” and “ COPY OF TENDER ,” as appropriate.
2.18.1	<p>Tender Closing Date: 11th May 2017 at 2.00PM</p> <p>Tender Opening Date: 11th May 2017 at 2.30PM</p>
2.22.2	<p>No correction of errors. The tender sum as submitted and read out during the tender opening shall be absolute and final and shall not be the subject of correction, adjustment or amendment in any way by any person or entity.</p>
	Delivery period shall be within 3 months after receipt of order.
2.24	<p><i>The following shall be the evaluation Criteria</i></p> <p>A) Mandatory preliminary evaluation criteria:</p> <ul style="list-style-type: none"> • Duly completed tender form. • Duly completed price schedule. • Manufacturer’s authorization letter. • Certificate of Incorporation/ Registration. • Valid business permit. • Duly filled Mandatory Confidential Business Questionnaire as provided. • Tender Security in the amount of KShs. 400,000/= or equivalent in a freely convertible currency, valid for 150 days from tender closing date. • Valid Tax Compliance Certificate issued by Kenya Revenue Authority (K.R.A). • Sequential serialization/pagination of all pages of the bid document. <p>B) Technical Evaluation Requirements</p>

	<ul style="list-style-type: none"> • Provide Catalogues, technical and descriptive literature. • Technical data sheets showing conformity to the technical specifications. • Compliance to all stated technical specifications. • Goods supplied shall be under 12 month's warranty. <p><i>C)Financial Evaluation criteria:</i></p> <ul style="list-style-type: none"> • Tenderers must quote for all items in the schedule of requirements in order to qualify as responsive. • Award will be to the total lowest evaluated bidder for all the items.
2.27	<p><i>KenGen may at its own discretion conduct due diligence on the recommended bidder to establish their ability to perform the contract.</i></p>

SECTION III: GENERAL CONDITIONS OF CONTRACT

3.1 Definitions

3.1.1 In this Contract, the following terms shall be interpreted as indicated:-

- (a) “The Contract” means the agreement entered into between the Procuring entity and the tenderer, as recorded in the Contract Form signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.
- (b) “The Contract Price” means the price payable to the tenderer under the Contract for the full and proper performance of its contractual obligations
- (c) “The Goods” means all of the equipment, machinery, and/or other materials, which the tenderer is required to supply to the Procuring entity under the Contract.
- (d) “The Procuring entity” means the organization purchasing the Goods under this Contract.
- (e) “The Tenderer” means the individual or firm supplying the Goods under this Contract.

3.2 Application

3.2.1 These General Conditions shall apply in all Contracts made by the Procuring entity for the procurement installation and commissioning of equipment

3.3 Country of Origin

3.3.1 For purposes of this clause, “Origin” means the place where the Goods were mined, grown or produced.

3.3.2 The origin of Goods and Services is distinct from the nationality of the tenderer.

3.4 Standards

3.4.1 The Goods supplied under this Contract shall conform to the standards mentioned in the Technical Specifications.

3.5 **Use of Contract Documents and Information**

3.5.1 The tenderer shall not, without the Procuring entity's prior written consent, disclose the Contract, or any provision therefore, or any specification, plan, drawing, pattern, sample, or information furnished by or on behalf of the Procuring entity in connection therewith, to any person other than a person employed by the tenderer in the performance of the Contract.

3.5.2 The tenderer shall not, without the Procuring entity's prior written consent, make use of any document or information enumerated in paragraph 3.5.1 above.

3.5.3 Any document, other than the Contract itself, enumerated in paragraph 3.5.1 shall remain the property of the Procuring entity and shall be returned (all copies) to the Procuring entity on completion of the Tenderer's performance under the Contract if so required by the Procuring entity

3.6 **Patent Rights**

3.6.1 The tenderer shall indemnify the Procuring entity against all third-party claims of infringement of patent, trademark, or industrial design rights arising from use of the Goods or any part thereof in the Procuring entity's country

3.7 **Performance Security**

3.7.1 Within **fifteen (15) days** of receipt of the notification of Contract award, the successful tenderer shall furnish to the Procuring entity the performance security in the amount specified in Special Conditions of Contract.

3.7.2 The proceeds of the performance security shall be payable to the Procuring entity as compensation for any loss resulting from the Tenderer's failure to complete its obligations under the Contract.

3.7.3 The performance security shall be denominated in the currency of the Contract, or in a freely convertible currency acceptable to the Procuring entity and shall be in the form of a bank guarantee or an irrevocable letter of credit issued by a reputable bank located in Kenya or abroad, acceptable to the Procuring entity, in the form provided in the tender documents.

3.7.4 The performance security will be discharged by the Procuring entity and returned to the Candidate not later than thirty (30) days following the date

of completion of the Tenderer's performance obligations under the Contract, including any warranty obligations, under the Contract

3.8 Inspection and Tests

3.8.1 The Procuring entity or its representative shall have the right to inspect and/or to test the goods to confirm their conformity to the Contract specifications. The Procuring entity shall notify the tenderer in writing in a timely manner, of the identity of any representatives retained for these purposes.

3.8.2 The inspections and tests may be conducted in the premises of the tenderer or its subcontractor(s), at point of delivery, and/or at the Goods' final destination. If conducted on the premises of the tenderer or its subcontractor(s), all reasonable facilities and assistance, including access to drawings and production data, shall be furnished to the inspectors at no charge to the Procuring entity.

3.8.3 Should any inspected or tested goods fail to conform to the Specifications, the Procuring entity may reject the equipment, and the tenderer shall either replace the rejected equipment or make alterations necessary to make specification requirements free of costs to the Procuring entity.

3.8.4 The Procuring entity's right to inspect, test and where necessary, reject the goods after the Goods' arrival shall in no way be limited or waived by reason of the equipment having previously been inspected, tested and passed by the Procuring entity or its representative prior to the equipment delivery.

3.8.5 Nothing in paragraph 3.8 shall in any way release the tenderer from any warranty or other obligations under this Contract.

3.9 Packing

3.9.1 The tenderer shall provide such packing of the Goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in the Contract.

3.9.2 The packing, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the Contract

3.10 Delivery and Documents

3.10.1 Delivery of the Goods shall be made by the tenderer in accordance with the terms specified by Procuring entity in its Schedule of Requirements and the Special Conditions of Contract

3.11 Insurance

3.11.1 The Goods supplied under the Contract shall be fully insured against loss or damage incidental to manufacturer or acquisition, transportation, storage, and delivery in the manner specified in the Special conditions of contract.

3.12 Payment

3.12.1 The method and conditions of payment to be made to the tenderer under this Contract shall be specified in Special Conditions of Contract

3.12.2 Payments shall be made promptly by the Procuring entity as specified in the contract

3.13 Prices

3.13.1 Prices charged by the tenderer for goods delivered and services performed under the Contract shall not, with the exception of any price adjustments authorized in Special Conditions of Contract, vary from the prices by the tenderer in its tender.

3.13.2 Contract price variations shall not be allowed for contracts not exceeding one year (12 months)

3.13.3 Where contract price variation is allowed, the variation shall not exceed 25% of the original contract price.

3.13.4 Price variation request shall be processed by the procuring entity within 30 days of receiving the request.

3.14. Assignment

3.14.1 The tenderer shall not assign, in whole or in part, its obligations to perform under this Contract, except with the Procuring entity's prior written consent.

3.15 Subcontracts

3.15.1 The tenderer shall notify the Procuring entity in writing of all subcontracts awarded under this Contract if not already specified in the tender. Such

notification, in the original tender or later, shall not relieve the tenderer from any liability or obligation under the Contract

3.16 Termination for default

3.16.1 The Procuring entity may, without prejudice to any other remedy for breach of Contract, by written notice of default sent to the tenderer, terminate this Contract in whole or in part

- (a) if the tenderer fails to deliver any or all of the goods within the period(s) specified in the Contract, or within any extension thereof granted by the Procuring entity
- (b) if the tenderer fails to perform any other obligation(s) under the Contract
- (c) if the tenderer, in the judgment of the Procuring entity has engaged in corrupt or fraudulent practices in competing for or in executing the Contract

3.16.2 In the event the Procuring entity terminates the Contract in whole or in part, it may procure, upon such terms and in such manner as it deems appropriate, equipment similar to those undelivered, and the tenderer shall be liable to the Procuring entity for any excess costs for such similar goods.

3.17 Liquidated Damages

3.17.1. If the tenderer fails to deliver any or all of the goods within the period(s) specified in the contract, the procuring entity shall, without prejudice to its other remedies under the contract, deduct from the contract prices liquidated damages sum equivalent to 0.5% of the delivered price of the delayed items up to a maximum deduction of 10% of the delayed goods. After this the tenderer may consider termination of the contract.

3.18 Resolution of Disputes

3.18.1 The procuring entity and the tenderer shall make every effort to resolve amicably by direct informal negotiation and disagreement or dispute arising between them under or in connection with the contract

3.18.2 If, after thirty (30) days from the commencement of such informal negotiations both parties have been unable to resolve amicably a contract dispute, either party may require adjudication in an agreed national or international forum, and/or international arbitration.

3.19 Language and Law

3.19.1 The language of the contract and the law governing the contract shall be English language and the Laws of Kenya respectively unless otherwise stated.

3.20 Force Majeure

3.20.1 The tenderer shall not be liable for forfeiture of its performance security or termination for default if and to the extent that its delay in performance or other failure to perform its obligations under the Contract is the result of an event of Force Majeure.

3.21 Taxes

3.21.1 "**Taxes**" means all present and future taxes, levies, duties, charges, assessments, deductions or withholdings whatsoever, including any interest thereon, and any penalties and fines with respect thereto, wherever imposed, levied, collected, or withheld pursuant to any regulation having the force of law and "Taxation" shall be construed accordingly.

3.21.2 Local Taxation

Nothing in the Contract shall relieve the Contractor and/or his Sub-Contractors from their responsibility to pay any taxes, statutory contributions and levies that may be levied on them in Kenya in respect of the Contract. The Contract Price shall include all applicable taxes and shall not be adjusted for any of these taxes.

3.21.3 The Contractor shall be deemed to be familiar with the tax laws in the Employer's Country and satisfied themselves with the requirements for all taxes, statutory contributions and duties to which they may be subjected during the term of the Contract.

3.21.4 In instances where discussions are held between the Employer and the Contractor regarding tax matters, this shall not be deemed to constitute competent advice and hence does not absolve the Contractor of their responsibility in relation to due diligence on the tax issue as per 3.21.2 above.

Tax Deduction

3.21.5 If the Employer is required to make a tax deduction by Law, then the deduction shall be made from payments due to the Contractor and paid directly to the Kenya Revenue Authority. The Employer shall upon remitting the tax to Kenya Revenue Authority furnish the Contractor with the relevant tax deduction certificates.

3.21.6 Where the Contractor is paid directly by the Financiers and the Employer is not able to deduct tax, then the Contractor will be required to pay the tax deduction to Kenya Revenue Authority in the name of the Employer and furnish the Employer with an original receipt thereof as evidence of such payment. In absence of the said evidence, the Employer will not process any subsequent payments to the Contractor.

Tax Indemnity

3.21.7 The Contractor shall indemnify and hold the Employer harmless from and against any and all liabilities, which the Employer may incur for any reason of failure by the Contractor to comply with any tax laws arising from the execution of the Contract whether during the term of the Contract or after its expiry.

3.21.8 The Contractor warrants to pay the Employer (within fourteen (14) days of demand by the Employer), an amount equal to the loss, liability or cost which the Employer determines has been (directly or indirectly) suffered by the Employer for or on account of the Contractor's Tax liability arising from the Contract.

3.21.9 Where the amount in 3.21.8 above remains unpaid after the end of the fourteen (14) days moratorium, the Employer shall be entitled to compensation for financing charges.

SECTION IV

SPECIAL CONDITIONS OF CONTRACT

- 4.1. Special Conditions of Contract shall supplement the General Conditions of Contract. Whenever there is a conflict, between the GCC and the SCC, the provisions of the SCC herein shall prevail over these in the GCC.
42. Special conditions of contract as relates to the GCC

REFERENCE OF GCC	SPECIAL CONDITIONS OF CONTRACT
3.7.1	Performance security <ul style="list-style-type: none">The performance security shall be in the amount of 10% of the contract price.
3.10.1	Delivery Period <ul style="list-style-type: none">The Goods shall be delivered within 3 months from the issuance of a Purchase Order.
3.12.3	Payment Terms and Conditions <ul style="list-style-type: none">KenGen's payment terms are 30 days upon receipt of certified invoices and delivery notes confirming that the invoiced material has been delivered and are in accordance with the contract. Advance Payment <ul style="list-style-type: none">Advance payment is not applicable
3.13.2.	No price variation is allowed under this contract.
3.18.2	Arbitration where necessary shall be by the Chartered Institute of Arbitrators Kenya Chapter or other International body.
	Warranty <ul style="list-style-type: none">Goods supplied shall be under 12 months warranty

Warranty

The Supplier warrants that the Goods supplied under the Contract are new, unused, of the most recent or current models, and that they incorporate all recent improvements in design and materials unless provided otherwise in the contract. The Supplier further warrants that all Goods supplied under this Contract shall have no defect, arising from design, materials, workmanship, or from any act or omission of the Supplier, that may develop under normal use of the supplied Goods in the conditions prevailing in the country.

The warranty period for the Goods is specified under the Special Conditions of Contract.

KenGen shall promptly notify the Supplier in writing of any claims arising under this warranty.

Upon receipt of such notice, the Supplier shall, within the period specified in the Special Conditions of Contract, and with all reasonable speed, repair or replace the defective Goods or parts thereof, without costs to KenGen.

If the Supplier, having been notified, fails to remedy the defect(s) **within the period specified or within a reasonable period**, KenGen may proceed to take such remedial action as may be necessary, at the Supplier's risk and expense and without prejudice to any other rights which KenGen may have against the Supplier under the Contract.

SECTION V

TECHNICAL SPECIFICATIONS

5.1 PARTICULARS

Notes Applicable to All Schedules:

1. The Goods to be supplied must be new and unused.
2. Relevant descriptive literature of the instrument spares showing conformity to technical specifications shall be provided with the bid.

Irrelevant literature downloaded from the Internet is not acceptable.

3. A tenderer may quote for supply of any or all the schedules.
4. Each schedule quoted for must be **COMPLETE** in order to qualify as responsive.
5. Award shall be based per schedule.

INSTRUMENT SPARES

Information on Usage

The instrument spares are for direct replacement of defective or worn out spares in the various plants.

Technical requirements

1. All the products to be supplied shall not be less than those required in the specifications.

Deviations from the requirements, if any, shall be explained in detail in writing, with supporting literature. The procuring entity reserves the right to reject products, if such deviations shall be found critical to the use and operation of the products.

SECTION VI

SCHEDULE OF REQUIREMENTS

SCHEDULE 1: OLKARIA I

Item	Description	Specifications	Manufacturer	Quantity
CONTROL VALVE SPARES				
1	Air Positioner Relay PPC/PPA	i. Model PPC 803 Supply: 8 bar Max. 120psi, 800kPa Inst: 0.2-1bar, 3-15psi, 20-100kPa	Koso	2
		ii. Model PPA 803 Supply: 8 bar Max. 120 psi, 800kPa Inst: 0.2-1bar, 3-15psi, 20-100kPa		2

Delivery period of the relay is 3 months from the issuance of a Purchase Order.

PRESSURE INSTRUMENT				
1	Pressure Switch	Type: CQ21-142 SPD TX1 Connection: 1/2 PF Element Type: Bourdon tube Tube Material: 316L SS Socket Material: SS Supply: 125V _{DC} Mounting: Straight Range: 0-30V bar Mounting		2
2	Pressure Switch	Type: – CQ21 -142 SPD TX1 connection -1/2 PF Element Type: Bourdon Tube Tube Material : 316LSS Socket Material: SS Supply DC 125V 0.5 A Range: 0-15V Bar Mounting Straight		2
3	Pressure gauge	Type: DHVU 1/2X100Dia Element Type: Bourdon Tube Tube Material : 316LSS Socket Material: SS Range: 0-15 Bar Mounting: Straight		2
TEMPERATURE INSTRUMENT				
1	Temperature Switch	Range: 0-150 degrees 3 pointer for indicator, high and trip Type: TBP-2 Ness	Kogyo Keiki	2
2	Thermometer	Range: 0-100 degrees Type: TBP-2 Capillary of 6 Metres		2
SPEED SENSOR				
1	Turbine Speed Meter	Scale Range: 0-4000rpm Input: 0-5mA FS: 5mA 0.25V _{DC} Diameter: 105mm Connection (from): MX-102 Type: R830Z	Shimadzu	2
LEVEL INSTRUMENTS				

1.	Condenser Level	Model:T810L 11231-72 Scale range: - 0 -1000MM Signal range: - 4-20MA	Shimadzu	2
2.	Cooling tower level	Model:T810L 11231-72 Scale range :NWL +200mm - -1000mm Signal Range: 4 -20MA	Shimadzu	2
3.	Pump & Seal pit level	Model:T810L 11231-72 Scale range :NWL +600mm - -600mm Signal Range: - 4 -20MA	Shimadzu	2
FLOW INSTRUMENTS				
1.	Flow switch	Model - SP-R PAT No. 525884 Nominal Dia. – 25mm Nozzle Dia. – 15mm Power Supply DC 110 0.27A Manufacturer - Nikkis Kogyo Co. Ltd.	Nikkis Kogyo Co. Ltd.	2
2.	Flow gauges	Type: - FC- SR AER 2-AD11V-0.9A Contact capacity 110Vdc 0.9A Fluid water temperature 15degrees ON -5.0lm - 5.7lm	Taiyo valve	2

SCHEDULE 2: OLKARIA II

Item	Description	Specifications	Manufacturer	Qty
CONTROL VALVE SPARES				
1	Butterfly Valve (Complete with Compatible Actuator)	<p>Service Conditions Process Fluid: Cooling Water (Geothermal Steam Condensate) Flow Rate (Normal): 292 m³/h Inlet Temperature: 21.3 °C Outlet pressure: 1.63 bar abs Inlet Pressure: 1.92 bar abs Specific Gravity: 0.999</p> <p>Valve Body/Bonnet Type: Butterfly ANSI B16.5 Class 150 Size: 250 mm Maximum Pressure: 4.5barg Temperature: 50 °C End connection: ANSI B16.5 Class 150 Body/Bonnet material: 316 SS FLC face finish: RF End external material: 316 SS Flow direction: Open forward Packing material: PTFE, V – ring</p> <p>Trim Rated travel: 90 degrees Plug material: 316SS Seat material: PTFE</p> <p>Actuator Type: Pneumatic (diaphragm) Fail Position: Closed Air Supply pressure: 5.5 to 8barg Input signal: On/Off solenoid/Energize to open Act orientation: Vertical actuator parallel mounting Hand wheel type: Gear operated with clutch Switches: 2 × SPDT at fully open and fully closed Air set with filter and gauge</p>	Fisher or equivalent	1

		Special Conditions/Accessories Materials/paint shall be resistant to hydrogen sulphide Bug screens required on all vent openings Valve to be bench set at factory and certificates provided		
2	Valve actuator complete with compatible valve positioner	Type:1052 Size:33 Operating range:0-33 Rotation:90° Action:PDTO Serial no:15965049 Pressure PSI Valve body Size:1 ½ Rotating:CL150 Body:STL Shaft:SST Type:V150 Ball Disk SST/PL Seat:COALY	Fischer or equivalent	2
PRESSURE INSTRUMENTS				
1	Diaphragm Pressure Gauge	Material: 316 Stainless Steel Lens: Laminated Safety Glass Pointer: Micro-Adjustable Mounting: Bottom Connection: ½" NPT Filling: Glycerine Accuracy: 1.0% Should be suitable for corrosive gaseous/liquids. Should withstand effects of H ₂ S. i. Dial: 4" Aluminium Range: -1 to 3bar ii. Dial: 6" Aluminium Range: -1 to 2bar iii. Dial: 6" Aluminium Range: -1 to 6bar	Ashcroft or equivalent	6 6 6

2	Pressure Switch	Electrical Connection: ½ NPT female conduit connection Pressure Connection: ½ NPT female conduit connection Wetted material: 316L stainless steel Diaphragm: 316L stainless steel Adjustable Range: 8 to 200psi Proof Pressure: 1000psig EL Rating: 11A.125/250VAC 5A.30VDC Serial Number: L8003905 Catalogue Number: B7685XCHFSJLNHTM07	Ashcroft	2
3	Benchtop Pneumatic Pressure Calibration Pump	Generated Pressure Range: 0.95bar vacuum to 40bar Pressure Resolution: 0.1mbar Accuracy: At least 0.2% of full scale Material: Ram/adapters: Stainless steel Body: Stainless steel/aluminium Seals: Buna-N Connections: (Finger-tight for both test gauge and reference gauge) Test gauge connection: ¼" BSP Reference gauge connection: ¼" BSP Weight: ≤ 3kg		2
LEVEL INSTRUMENTS				

1	External Cage Float Operated Magnetic Level Switch	<p>Process Temperature: Up to 250°C</p> <p>Process Pressure: Up to 275psig (@ 38°C)</p> <p>Specific Gravity: 0.74</p> <p>Cage and Process Connection: 316L stainless steel</p> <p>Float and Trim: 316 stainless steel</p> <p>Switch Ratings: 10A, 120V_{AC}</p> <p>Switch Output & Type: DPDT dry contact</p> <p>Switch Action: Break before Make</p> <p>Cable Entry: 1" NPT</p> <p>Enclosure: Weather Proof; Hermetically Sealed, NEMA-4X, IP67</p> <p>Cage:</p> <p>Type: Flanged side/side</p> <p>Upper Connection: 1" 150# RF Flanged Size</p> <p>Lower Connection: 1" 150# RF Flanged Size</p> <p>Deadband: +/- 20mm Float Travel</p> <p>Model Number: XB41-DS30-CB9</p>	Magnetrol or Equivalent	4
TEMPERATURE INSTRUMENTS				
1	Armoured Thermocouple	<p>Element: E Type</p> <p>Class: SP</p> <p>Operating Temperature Range: 0 to 150°C</p> <p>Serial No.: UT2158OM 09</p>	Okazaki	3
2	Thermocouple transducer	<p>Model: JXP-5-29-88</p> <p>Input: E(0-150°C)</p> <p>Output 1:DC 4-20mA</p> <p>Output 2:DC 4-20mA</p>	TOYO KIEKI	4

3	Temperature Alarm Setter	Model:DSP-5-8-H/HH Input: DC 4-20mA Alarm contact:H/HH	TOYO KIEKI	4
---	--------------------------	--	------------	---

SCHEDULE 3: OLKARIA IAU & IV

Item	Description	Specifications	Manufacturer	Quantity
CONTROL VALVE SPARES				
1	Valve Positioner	<p>Model: YT-2500 Acting Type: Single/Double Input Signal: 4-20mA DC Minimum Current Signal: 3.2mA(Standard), 3.8mA (HART included) Supply Pressure: 0.14~0.7MPa (1.4~7bar) Stroke: 10~150 mm 0~90° Impedance: Max.460Ω @ 20mA DC Air Connection: PT, NPT 1/4 Gauge Connection: PT, NPT 1/8 Conduit Entry: PF(G) 1/2 Protection Grade: IP67 Explosion Proof: Ex d IIC T6 Ambient Temperature: Operating Temp.: -30~80°C Explosion Proof Temp.: -40~70 °C (T6) / -40~85°C (T5) Linearity: ±0.5% F.S. Hysteresis: 0.5% F.S. Sensitivity: ±0.2% F.S Repeatability: ±0.3% F.S. Flow Capacity: 70 LPM (Sup.= 0.14MPa) Air Consumption: 0 LPM (Sup.= 0.14MPa when idle) Output Characteristic: Linear, Quick Open, EQ%, User Set (16 point) Vibration: No Resonance up to 100Hz @ 6G Humidity: 5-95% RH @ 40°C Communication: HART Communication Feedback Signal: 4~20mA (DC 10~30V) Material: Aluminum Die-casting Weight: 1.5kg Painting: Epoxy Polyester Powder Coating <ul style="list-style-type: none"> • Should have an LCD screen that makes it easy to inspect the state of the positioner in the field. Various valve characteristics such as linear, quick open and equal percentage should be available as options. <ul style="list-style-type: none"> • PID parameters should be adjusted easily in the field by button. </p>	Young Tech CO.	4 (Single Acting) 2 (Double Acting)

2	Valve Positioner	<p>Model No.3200MD-28-N6-E-D4-40-0S-0F</p> <p>Electrical Specifications Power Supply: Two wire, 4–20mA, 10 to 30V_{DC} Communication: HART Protocol Minimum Operating Current: 3.85mA without AO Board Maximum Voltage: 30.0VDC</p> <p>Environmental Conditions Operating Temperature Range: standard (-240 to 80°C) Operating Humidity: 0 to 100% non-condensing</p> <p>Physical Specifications Housing Material: Cast, powder aluminum, stainless steel Soft Goods: Buna-N/fluorosilicone Weight: 4kg to 10kg Protection: IP66</p> <p>Positioner Specifications Dead band: <0.1% full scale Repeatability: <0.05% full scale Linearity: <0.5% (Rotary) Air Consumption: <0.3SCFM(0.5Nm³/hr) @ 60 psi(4bar g) Air capacity: 12SCFM@6psi(4bar g)(0.27Cv)</p> <p>4 to 20mA Analogue Output Specifications Potential Range of Rotation: 40 to 95°C Power Supply Range: 12.5 to 40V_{DC} (24V_{DC} typical) Current Signal Output: 4–20mA Linearity: 1.0 % F.S Repeatability: 0.25% Hysteresis: 1.0% F.S The positioner should be configurable through the local user interface. The interface should allow the user to configure the basic operation of the positioner, tune the response, and calibrate the positioner without additional tools or configurators. Should control both double and single acting actuators with linear or rotary mountings.</p> <p>Complete with Indication gauges</p>	Flowserve	2
---	------------------	--	-----------	---

3	Digital Valve Positioner	<p>Electrical Rating: 24V_{DC}, 4-20mA Easy to use user interface for local Configuration. HART Protocol communication, Local graphic LCD display and feedback Option. Double acting functioning.</p> <p>THREADS Cable entries:1/2"-14NPTF Supply: C- , C+: G 1/4" - 18NPTF Exhausts: G 1/4" Gauges: 1/8" -27NPTF Part No.: D3ENU-K23PVA-Z5TM Complete with Indication gauges</p>	Flowserve	4
4	Valve Positioner	<p>Standard Version-standard Diagnostics Single Acting Standard Flow No Display Hard Ware Version 3 4 – 20 mA Hart Communications. Accuracy:+/-0.5% Full Scale Option Board: Position Retransmit and Limit Switches Complete with pressure indication gauges. Flow Characteristic: Linear and Equal Percentage Position Travel sensor: Rotary Agency Approval: ATEX/FM/CSA/Intrinsic Safety & Expf Model No:SVI II 21113121</p>	Masoneilan	4

5	Flow/Volume Booster	<p>Max Output pressure:150psig Maximum Supply Pressure:250psig Flow Capacity: Adjustable –from 7.0bar to 1.5bars Exhaust Capacity: Downstream Pressure 150 Set point(Water Column):1” Ratio Accuracy(% of 100psig):3.0 Supply Pressure Effect:0.10psig Pipe Size:1/2”NPT Option: Must have a By Pass Valve Ambient Temperature-40⁰F to 200⁰F, (-40⁰C to 93.3⁰C) Hazardous Locations Acceptable for use in Zones 1 and 2 for gas atmosphere; Groups IIA and IIB and Zones 21 and 22 for dust atmospheres Materials of Construction Body and Housing Aluminum Trim. . Zinc Plated Steel, Brass Diaphragm. Nitrile on Dacron Cat No.4514A1</p>	FAIRCHILD Industrial Products Company.	2
	Flow/Volume Booster	<p>Model: YT-310N1 Max. Supply pressure 1Mpa(10 bar) Max. Signal/Out pressure 0.7Mpa(7 bar) Signal port 1/4 Supply port/Out 3/4 Material Aluminium diecasting Linearity: ±1% F.S.</p>	Young Tech CO.	2
	Flow/Volume Booster	<p>Model: YT-310N1 Max. Supply pressure 1Mpa(10 bar) Max. Signal/Out pressure 0.7Mpa(7 bar) Signal port 1/4 Supply port/Out 1/4 Material Aluminium diecasting Linearity: ±1% F.S.</p>	Young Tech CO.	2

6	Flow/Volume Booster	<p>Max Output pressure:150psig Maximum Supply Pressure:250psig PORT Size:3/4",Forward Cv 5,Exhaust Cv 5 Port Thread: NPTF, Elastomer: Nitrile Remote Pressure Sensor: No feedback Port Trim: Zinc Plated Steel Ambient Temperature -40°F to 200°F, (-40°C to 93.3°C) Hazardous Locations Acceptable for use in Zones 1 and 2 for gas atmosphere; Groups IIA and IIB and Zones 21 and 22 for dust atmospheres Materials of Construction Body and Housing Aluminum Trim Zinc Plated Steel , Brass Diaphragm Nitrile on Dacron Cat No.4816ANNF</p>	FAIRCHILD Industrial Products Company.	2
6	Solenoid Valve	<p>Function:5/2 Single Port Size:G1/4, Fluids: Compressed air & inert gases Pressure: 0.15 – 1.0 Eff. Sectional Area: 18mm² Ambient & Fluid Temp: 5 -60°C Response Time: 30ms Max. Working Frequency:5c/sec Coil Insulation Class: F-Class or Equivalent Permissible Voltage Variation:±10% of rated voltage Off Min .Residual Voltage:10% or less DC Power Consumption:DC:2.5W Return Method: Air + Spring Manual Operator: Push Button Non – Locking Connector type: DIN Connector Voltage: DC24V Model No.HNV3101-IP-HC 2-CN2-3,24Vdc, kgf/cm2</p>	HANWHA,	4

PRESSURE INSTRUMENTS				
6	Pressure (Vacuum) Switch	<p>Adjustable Range: 150mbara to 800mbara Series: 953 Switch form: Two SPDT Process Connection: C-1/4", D-3/8", E-1/2" Connection Type: B-PF, C-PT, D-NPT, E-NPT(F)-1/2"NPT(F) only Unit: H-Bar, I-MPa, J-kPa, S-mBar Process Connection/Element Material: 316SS Case and Cover: Silver gray finished and Aluminium Repeatability: ±1.0% of adjustable range Working Temperature: Ambient: -20 to +65°C Fluid Temperature: Max 100°C Approval by Standards: Ex d IIC T6(KGS) II 2 G (LCIE 06 ATEX 6073X) IEC Ex KGS – 04-0001 Ex d IIC T6 (Tam=-20-60°C) Electrical Rating: 15A 125V_{AC}, 250V, 0.5A 125V_{DC}, 0.25A 250V_{DC}</p>	Wise Controls	2
7	Pressure transmitter	<p>Rosemount 2051T In-line pressure transmitter Pressure type: Gauge pressure (G)Max pressure: 20.3 bar Operating range (cal): 0-20bar Output Hart: 4-20mA (with Digital Signal Based on HART Protocol) Process connection style: 1/2 NPT female Isolating diaphragm: 316L SST Process connection wetted parts material: 316L SST Sensor fill fluid: silicone Housing material: Aluminium Conduit entry size: 1/2-14 NPT Manifold assemblies: Assemble to Rosemount 306 Integral Manifold Mounting bracket: Bracket for 2-in. pipe or panel mounting, All SST Product certifications: ATEX Flameproof Display options: LCD display Hardware adjustments: Zero and span configuration buttons.</p>	Rosemount	2

		Terminal blocks: Transient protection terminal block Calibration certification: Calibration certificate Material traceability certification: Material traceability certification per EN 10204 3.1		
8	PRESSURE TRANSMITTER	Calibration Pressure Range 0 To 6 Barg. Transmitter Output 4 – 20mA Hart Mounting: Yoke/2” Pipe Stanchion. Element .Material:316SST. Wetted .Material:316SST. Vent/Drain Plug .Material:316SST. Type: 2 Wire. Housing Material: Low –copper aluminium Conduit Entry: 3/4”NTP. Transient Protection: Yes. Process Connection: 1/2”NPT/Female. Model :No.2051TG2A2B21AS5B4E1M5D4T1Q4 Q8	Emerson	1
9	LIQUID FILLED PRESSURE GAUGE	Type: Direct Reading Mounting: Local Dial Size:100mm Dial Colour: WHITE Case material:316ss Ring Type: BAYONET Accuracy:±1.0% OF Full Scale Over range Protection:1.3 X Of Full scale Blow Out Protection: Back Window :Safety Glass Filled Fluid : GYCERINE Pressure Element: Bourdon Tube Element Material:316SS Socket Matrial:316SS Movement Matrial:304SS Connection:1/2”NPT Male, Bottom Range:0 – 16 Barg	Wise	2

10	Pressure Transmitter	<p>Calibration Pressure Range -1 To 1barg Barg.</p> <p>Transmitter Output 4 – 20mA Hart</p> <p>Mounting: Yoke/2” Pipe Stanchion.</p> <p>Element .Material:316SST.</p> <p>Wetted .Material:316SST.</p> <p>Vent/Drain Plug .Material:316SST.</p> <p>Type: 2 Wire.</p> <p>Housing Material: Low –copper aluminium</p> <p>Conduit Entry: 3/4”NTP.</p> <p>Transient Protection: Yes.</p> <p>Process Connection: 1/2”NPT/Female.</p> <p>Model No.2051TG2A2B21AS5B4E1M5D4T1Q4Q8</p>	ROSEMOUNT	2
11	Differential pressure level transmitter	<p>Special type level transmitter</p> <p>Output: Hart 4 – 20mA</p> <p>Supply: 10.5 - 42.4Vdc</p> <p>Serial no: 02880557</p> <p>Max W.P. 275psi/19.0bar</p> <p>Calibration range: -1138.5 To 71.9mmH2O</p> <p>Model:2051CD2A22A1AS2B4E1M5D4T1C1Q4Q8</p>	Rosemount	2
12	EHC pressure transmitter	<p>3051T In-line pressure transmitter</p> <p>Pressure type: Gauge pressure (G)</p> <p>Operating range (cal): 0-275.79bar(0-27579 kPa)</p> <p>Output Hart: 4-20mA (with Digital Signal Based on HART Protocol)</p> <p>Process connection style: G¹/₂ A DIN 16288 (range 1-4 only)</p> <p>Isolating diaphragm: 316L SST</p> <p>Process connection wetted parts material: 316L SST</p> <p>Sensor fill fluid: silicone</p> <p>Housing material: Aluminum</p> <p>Conduit entry size: ¹/₂–14 NPT</p> <p>Manifold assemblies: Assemble to Rosemount 306 Integral Manifold</p> <p>Mounting bracket: Bracket for 2-in. pipe or panel mounting, All SST</p> <p>Product certifications: ATEX Flameproof</p> <p>Display options: LCD display</p> <p>Hardware adjustments: Zero and span configuration buttons</p> <p>Terminal blocks: Transient protection terminal block</p> <p>Calibration certification: Calibration certificate</p>	Rosemount	2

OTHER INSTRUMENTS				
13	Flow Switch	Type: SU6LW-FR-PLS 834 , Max Pressure: 10barg Max Temperature: 70°C Contact Capacity: 24V _{DC} Over: 8.10l/min C-A OFF Under: 6.00l/min C-A ON	TAIYO VALVE	4
14	PH METER MONITORING CELLS	Model no. AP303/2201001 i.d 4840/04/13 3K220000169429 Sensor type: Notched Tagged Sensor Terminations for Direct Connection to Transmitter Temperature Compensation: 3 wire pH with temperature compensation Should have an integral cable of 3Metres length Measuring PH range(standard yellow glass) 0 to 14 Redox(ORP) measuring range:-2000 to 2000mV Measurement type: Flow application Temperature Range: 0 to 105 ⁰ C Pressure maximum: 6bar(90psi) @25 ⁰ C Temperature compensator: Balco 3kΩ Sensor Insertion length :28.0mm(1.1in) Connection to flash cell:3/4in.NPT Wetted materials pH electrode-Glass Redox(ORP) electrode - Platinum Junction - PTFE Body - PVDF(Kynar) Immersion guard - PVC	ABB	4
15	Electronic Capacity Control	Input Voltage: 240V _{AC} Control Signal Input: 4-20mA Position Feedback Output: 4-20mA Accuracy: ± 0.5% Travel Time: 10 seconds Enclosure: NEMA 4X (Hazardous Location) Model: PPRX512RMH For use with Milton Roy Pumps MROY RA1117105XSESEE2NN pumps.	Milton Roy	4
16	Handheld portable radios/Walkie talkie	Handheld portable radio Voice operated transmission Push to talk power boost Capability to operate over long range. Rechargeable battery. Long lasting battery with low battery alert. Built –in LED flashlight	Reputable manufacturer	6

SCHEDULE 4: OLKARIA WELLHEAD PLANTS

Item	Description	Specifications	Manufacturer	Quantity
PRESSURE INSTRUMENTS				
1	Pressure Switch	Order code: PMC51-CK25/0 Serial No.: H4003C01128 Ext Order code: PMC51-AA12QA1PGBGCJJ Input Pressure: -1-10 Bar Rated power supply: 11.5-45VDC Output: 4-20mA Span: 0.5/10bar	Cerabar	4
VIBRATION INSTRUMENTS				
2	Vibration sensor (Proximity Probe)	Order code/Model No. FL-202F08A-M2-00-05-10/GEO Armoured Threaded Size: M10 X 1 Unthreaded Length: 0mm Threaded Length: 50mm Cable Length: 1.0m Geothermal Specs	Shinkawa	10
3	Vibration sensor (Proximity Probe)	Order code/Model No. FL-202F05A-M2-00-05-10/GEO Armoured Threaded Size: M8 X 1 Unthreaded Length: 0mm Threaded Length: 50mm Cable Length: 1.0m Geothermal Specs	Shinkawa	10
4	Vibration Driver (Transducer)	Order code/Model No. FK-202F1-3-1/GEO System cable length: 5m Geothermal Specs	Shinkawa	4
5	Vibration Sensor Extension Cable	Order code/Model No. FW-202FA-40/GEO Armored Cable length: 4M Geothermal Specs	Shinkawa	4

**SECTION VII
PRICE SCHEDULE FOR GOODS**

SCHEDULE 1: OLKARIA I INSTRUMENT SPARES

Item	Description	Quantity	Unit Price	Total Cost
1	Air Positioner Relay PPC/PPA i. Model PPA 803 ii. Model PPA 803	2 2		
2	Pressure Switch 0-15	2		
3	Pressure Switch 0-30	2		
4	Temperature Switch	2		
5	Thermometer	2		
6	Turbine Speed Meter	2		
7	Condenser level	2		
8	Cooling tower level	2		
9	Pump & Seal pit level	2		
10	Flow switch	2		
11	Flow gauge	2		
FOR LOCAL SUPPLIERS				
Sub-Total				
Discount (%) if any				
Other Charges e.g. transport, handling				
Total Cost to Olkaria Power Station				
Country of Origin				
Currency of Tender				
Delivery Period				
FOR OVERSEAS SUPPLIERS				
Sub-Total				
Discount (%) if any				
Air / Sea freight charges to Nairobi / Mombasa Port				
Other Charges (if any)				
Total Cost & Freight (CPT) Jomo Kenyatta International Airport, Nairobi				
Country of Origin				
Currency of Tender				
Delivery Period				

TENDERER'S NAME: _____

TENDERER'S SIGNATURE _____

COMPANY'S RUBBER STAMP _____

SCHEDULE 2: OLKARIA II INSTRUMENT SPARES

Item	Description	Quantity	Unit Price	Total Cost
1	Butterfly Valve (Complete with Compatible Actuator)	1		
2	Valve Actuator	2		
3	Diaphragm Pressure Gauge (-1 to 3bar)	6		
4	Diaphragm Pressure Gauge (-1 to 2bar)	6		
5	Diaphragm Pressure Gauge (-1 to 6bar)	6		
6	Pressure Switch	2		
7	Pneumatic Pressure calibration Pump	2		
8	Float operated magnetic level switch	4		
9	Armoured Thermocouple	3		
10	Thermocouple Transducer	4		
11	Temperature Alarm setter	4		
FOR LOCAL SUPPLIERS				

Sub-Total	
Discount (%) if any	
Other Charges e.g. transport, handling	
Total Cost to Olkaria Power Station	
Country of Origin	
Currency of Tender	
Delivery Period	
FOR OVERSEAS SUPPLIERS	
Sub-Total	
Discount (%) if any	
Air / Sea freight charges to Nairobi / Mombasa Port	
Other Charges (if any)	
Total Cost & Freight (CPT) Jomo Kenyatta International Airport, Nairobi	
Country of Origin	
Currency of Tender	
Delivery Period	

TENDERER'S NAME: _____

TENDERER'S SIGNATURE _____

COMPANY'S RUBBER STAMP _____

SCHEDULE 3: OLKARIA IAU & IV INSTRUMENT SPARES

Item	Description	Quantity	Unit Price	Total Cost
1	Valve Positioner <input type="checkbox"/> Single Acting <input type="checkbox"/> Double Acting	4 2		
2	Valve Positioner	2		
3	Digital Valve Positioner	4		
4	Valve Positioner	4		
5	Flow/Volume Booster	2		
6	Flow/Volume Booster (3/4)	2		
7	Flow/Volume Booster (1/4)	2		
8	Flow/Volume booster	2		
9	Solenoid Valve	4		
10	Pressure (Vacuum Switch)	2		
11	Pressure Transmitter	2		
12	Pressure Transmitter	1		
13	Liquid filled pressure Gauge	2		
14	Pressure Transmitter	2		
15	Differential pressure level transmitter	2		
16	EHC Pressure transmitter	2		
17	Flow Switch	4		
18	PH meter monitoring cells	4		
19	Electronic Capacity Control	4		
20	Hand held portable radio	6		
FOR LOCAL SUPPLIERS				
Sub-Total				
Discount (%) if any				
Other Charges e.g. transport, handling				
Total Cost to Olkaria Power Station				
Country of Origin				
Currency of Tender				
Delivery Period				
FOR OVERSEAS SUPPLIERS				
Sub-Total				
Discount (%) if any				
Air / Sea freight charges to Nairobi / Mombasa Port				

Other Charges (if any)	
Total Cost & Freight (CPT) Jomo Kenyatta International Airport, Nairobi	
Country of Origin	
Currency of Tender	
Delivery Period	

TENDERER'S NAME: _____

TENDERER'S SIGNATURE _____

COMPANY'S RUBBER STAMP _____

SCHEDULE 4: OLKARIA WELLHEADS INSTRUMENT SPARES

Item	Description	Quantity	Unit Price	Total Cost
1	Pressure Switch	4		
2	Vibration sensor (M10X1)	10		
3	Vibration sensor (M8X1)	10		
4	Vibration Driver (Transducer)	4		
5	Vibration Sensor Extension Cable	4		
FOR LOCAL SUPPLIERS				
Sub-Total				
Discount (%) if any				
Other Charges e.g. transport, handling				
Total Cost to Olkaria Power Station				
Country of Origin				
Currency of Tender				
Delivery Period				
FOR OVERSEAS SUPPLIERS				
Sub-Total				
Discount (%) if any				
Air / Sea freight charges to Nairobi / Mombasa Port				
Other Charges (if any)				
Total Cost & Freight (CPT) Jomo Kenyatta International Airport, Nairobi				
Country of Origin				
Currency of Tender				
Delivery Period				

TENDERER'S NAME: _____

TENDERER'S SIGNATURE _____

COMPANY'S RUBBER STAMP _____

**SECTION VIII
STANDARD FORMS**

8.1 FORM OF TENDER

Date _____
Tender No. _____

To: _____

[name and address of procuring entity]

Gentlemen and/or Ladies:

1. Having examined the tender documents including Addenda Nos. *[insert numbers]*, the receipt of which is hereby duly acknowledged, we, the undersigned, offer to supply deliver, install and commission (..... *(insert equipment description)* in conformity with the said tender documents for the sum of *(total tender amount in words and figures)* or such other sums as may be ascertained in accordance with the Schedule of Prices attached herewith and made part of this Tender.

2. We undertake, if our Tender is accepted, to deliver install and commission the equipment in accordance with the delivery schedule specified in the Schedule of Requirements.

3. If our Tender is accepted, we will obtain the guarantee of a bank in a sum of equivalent to _____ percent of the Contract Price for the due performance of the Contract , in the form prescribed by *(Procuring entity)*.

4. We agree to abide by this Tender for a period of **120 days** from the date fixed for tender opening of the Instructions to tenderers, and it shall remain binding upon us and may be accepted at any time before the expiration of that period.

5. This Tender, together with your written acceptance thereof and your notification of award, shall constitute a Contract, between us, subject to signing of the Contract by the parties.

6. We understand that you are not bound to accept the lowest or any tender you may receive.

Dated this _____ day of _____ 20 _____

[signature]

[in the capacity of]

Duly authorized to sign tender for an on behalf of _____

8.2 MANDATORY CONFIDENTIAL BUSINESS QUESTIONNAIRE FORM

(Must be filled by all applicants or Tenderers' who choose to participate in this tender)

Name of Applicant(s).....

You are requested to give the particulars in Part 1 and either Part 2 (a), 2 (b) or 2 (c), whichever applies to your type of business. Part 2 (d) to part 2 (i / j) must be filled. You are advised that giving wrong or false information on this Form will lead to automatic disqualification/termination of your business proposal at your cost.

Part 1 – General

Business Name:.....Certificate of Incorporation /
Registration No. Location of business premises:
Country Physical address
Town Building.....
Floor.....Plot No.
Street / Road Postal Address
Postal / Country Code.....Telephone No's.....
Fax No's.E-mail address
Website
Contact Person (Full Names) Direct / Mobile No's.....
Title Power of Attorney (Yes / No)
If **yes**, attach written document.
Nature of Business (Indicate whether manufacturer, distributor, etc)

(Applicable to Local suppliers only)

Local Authority Trading License No. Expiry Date
Value Added Tax No.....
Value of the largest single assignment you have undertaken to date (USD/KShs)
.....
Was this successfully undertaken? **Yes / No**.(If **Yes**, attach reference)
Name (s) of your banker (s)
.....
Branches Tel. No's.

Part 2 (a) – Sole Proprietor (if applicable)

Full names
Nationality..... Country of Origin.....
.....
Company Profile (Attach brochures or annual reports in case of public company)

Part 2 (b) – Partnerships (if applicable)

Give details of partners as follows:

Full Names Nationality Citizenship Details Shares

1.
2.
Company Profile (Attach brochures)

Part 2 (c) – Registered Company (if applicable - as per the CR12 form)

Private or public
Company Profile (Attach brochures or annual reports in case of public companies)
State the nominal and issued capital of the Company
Nominal KShs
Issued KShs

List of top ten (10) shareholders and distribution of shareholding in the company. Give details of all directors as follows:-

Full Names Nationality Citizenship Details Shares

1.....
2.....

Part 2 (d) – Debarment

I/We declare that I/We have not been debarred from any procurement process and shall not engage in any fraudulent, corrupt, coercive and obstructive acts with regard to this or any other tender by the KENGEN and any other public or private institutions.

Full Names
.....
Signature
Dated this day of 2015.
In the capacity of
.....
Duly authorized to sign Tender for and on behalf of

Part 2 (e) – Bankruptcy / Insolvency / receivership.

I/We declare that I/We have not been declared bankrupt or insolvent by the competent Authorities in Kenya and neither are we under receivership:

Full Names
.....
Signature
Dated this day of 2015.
In the capacity of
.....
Duly authorized to sign Tender for and on behalf of

Part 2 (f) – Criminal Offence

I/We, (Name (s) of Director (s)):-

a)
b)

Have not been convicted of any criminal offence relating to professional conduct or the making of false statements or misrepresentations as to its qualifications to enter into a procurement contract within a period of three (3) years preceding the commencement of procurement proceedings.

Signed
For and on behalf of M/s
.....
In the capacity of
.....
Dated this day of 2015.
Suppliers' / Company's Official Rubber Stamp
.....

Part 2 (g) – Conflict of Interest

I/We, the undersigned state that I / We have no conflict of interest in relation to this procurement:

a)
b)
For and on behalf of M/s
In the capacity of
Dated this day of 2015
Suppliers' / Company's Official Rubber Stamp
.....

Part 2 (h) – Interest in the Firm:

Is there any person/persons in KENGEN or any other public institution who has interest in the Firm? Yes/No
 (Delete as necessary) Institution

.....
 (Title) (Signature) (Date)

Part 2(i) – Experience:

Please list here below similar projects accomplished or companies / clients you have supplied with similar items or materials in the last **5** years.

	Company Name	Country	Contract/Order No.	Value	Contact person (Full Names)	E-mail address	Cell phone No.
1							
2							

Part 2 (i or j) – Bank account details:

AGPO firms must provide evidence from their bank that the account to which KenGen shall make payment has a youth or a woman or a PWD listed in the **CR12 form/partnership deed/sole proprietor certificate** as a MANDATORY signatory of that account,- **Sec.157 (11) of PPADA:**

Account No:.....**Name of the person(s) in the CR12 form OR in the partnership deed**
OR **in** **the** **sole** **proprietor**
certificate...../.....

ID No(s):...../**Signature and stamp of the authorized Banker**
Representative.....**Date**.....

Part 2(j or k) – Declaration

I / We, the undersigned state and declare that the above information is correct and that I / We give KENGEN authority to seek any other references concerning my / our company from whatever sources deemed relevant, e.g. Office of the Registrar of Companies, Bankers, etc.
 Full names

.....
 Signature.....

For and on behalf of M/s
 In the capacity of

.....
 Dated thisday of2015.

Suppliers' / Company's Official Rubber Stamp

8.3 TENDER SECURITY FORM

(To be on the Banks Letterhead)

WHEREAS [*name of the tenderer*]
(hereinafter called “the tenderer”) has submitted its tender dated
..... [*date of submission of tender*] for
..... [*name and/or description of the equipment*]
(hereinafter called “the Tender”)

KNOW ALL PEOPLE by these presents that **WE** of
..... having our registered office at
(hereinafter called “the Bank”), are bound unto the **Kenya Electricity
Generating Company Limited** (hereinafter called “the Procuring entity”) in
the sum of for which payment well and truly to be made
to you, the Bank binds itself, its successors, and assigns by these presents.

Sealed with the Common Seal of the said Bank this ____ day of _____ 20

THE CONDITIONS of this obligation are:-

1. If the tenderer withdraws its Tender during the period of tender validity specified by the tenderer on the Tender Form; or
2. If the tenderer, having been notified of the acceptance of its Tender by the Procuring entity during the period of tender validity:
 - (a) fails or refuses to execute the Contract Form, if required; or
 - (b) fails or refuses to furnish the performance security in accordance with the Instructions to tenderers;

We undertake to pay the Procuring entity up to the above amount upon receipt of its first written demand, without the Procuring entity having to substantiate its demand, provided that in its demand the Procuring entity will note that the amount claimed by it is due to it, owing to the occurrence of one or both of the two conditions, specifying the occurred condition or conditions.

This tender guarantee will remain in force up to and including thirty (30) days after the period of tender validity, and any demand in respect thereof should reach the Bank not later than the above date.

[*Signature of the bank*]_____

(Amend accordingly if provided by Insurance Company)

8.4 CONTRACT FORM

THIS AGREEMENT made the _____ day of _____ 20 ____ between
..... [name of **the Employer**] of [country of **the Employer**] (hereinafter
called "**the Employer**") of the one part and [name of **the Supplier**] of
..... [city and country of **the Supplier**] (hereinafter called "**the Supplier**") of the other
part;

WHEREAS the Employer invited tenders for] and has accepted a tender by the
tenderer for the supply of in the sum of [contract
price in words and figures] (hereinafter called "the Contract Price).

NOW THIS AGREEMENT WITNESSETH AS FOLLOWS:

1. In this Agreement words and expressions shall have the same meanings as are
respectively assigned to them in the Conditions of Contract referred to:
2. The following documents shall be deemed to form and be read and construed as part of
this Agreement viz:
 - (a) the Tender Form and the Price Schedule submitted by the tenderer
 - (b) the Schedule of Requirements
 - (c) the Technical Specifications
 - (d) the General Conditions of Contract
 - (e) the Special Conditions of contract; and
 - (f) the Procuring entity's Notification of Award and Tenderer's Acceptance
 - (g) Applicable addenda and clarifications
3. In consideration of the payments to be made by the Procuring entity to the tenderer as
hereinafter mentioned, the tenderer hereby covenants with the Procuring entity to
provide the goods and to remedy defects therein in conformity in all respects with the
provisions of the Contract
4. The Procuring entity hereby covenants to pay the tenderer in consideration of the
provisions of the goods and the remedying of defects therein, the Contract Price or
such other sum as may become payable under the provisions of the Contract at the
times and in the manner prescribed by the contract.

IN WITNESS whereof the parties hereto have caused this Agreement to be executed in
accordance with their respective laws the day and year first above written.

Signed by _____ the _____ (for the Procuring entity

Signed by _____ the _____ (for the tenderer in the presence of _____

(Amend accordingly if provided by Insurance Company)

8.5 **PERFORMANCE SECURITY FORM**

(To be on the Banks Letterhead)

To

[name of Procuring entity]

WHEREAS *[name of tenderer]* (hereinafter called “the tenderer”) has undertaken, in pursuance of Contract No. _____
_____ *[reference number of the contract]* for dated _____ 20 ____
_____ to supply *[description of goods]* (hereinafter called “the Contract”).

AND WHEREAS it has been stipulated by you in the said Contract that the tenderer shall furnish you with a bank guarantee by a reputable bank for the sum specified therein as security for compliance with the Tenderer’s performance obligations in accordance with the Contract.

AND WHEREAS we have agreed to give the tenderer a guarantee:

NOW THEREFORE WE hereby affirm that we are Guarantors and responsible to you, on behalf of the tenderer, up to a total of *[amount of the guarantee in words and figure]* and we undertake to pay you, upon your first written demand declaring the tenderer to be in default under the Contract and without cavil or argument, any sum or sums within the limits of *[amount of guarantee]* as aforesaid, without you needing to prove or to show grounds or reasons for your demand or the sum specified therein.

This guarantee is valid until the _____ day of _____ 20 ____

Signed and seal of the Guarantors

[name of bank or financial institution]

[address]

[date]

8.6 MANUFACTURER'S AUTHORIZATION FORM

To *[name of the Procuring entity]*

WHEREAS *[name of the manufacturer]* who are established and reputable manufacturers of *[name and/or description of the goods]* having factories at *[address of factory]* do hereby authorize *[name and address of Agent]* to submit a tender, and subsequently negotiate and sign the Contract with you against tender No. *[reference of the Tender]* for the above goods manufactured by us.

We hereby extend our full guarantee and warranty as per the General Conditions of Contract for the goods offered for supply by the above firm against this Invitation for Tenders.

[signature for and on behalf of manufacturer]

Note: This letter of authority should be on the letterhead of the Manufacturer and should be signed by a person authorized.