



KenGen

**KENYA ELECTRICITY GENERATING COMPANY
LIMITED**

KGN-GDD-051-2017

**TENDER FOR SUPPLY, INSTALLATION, TESTING AND
COMMISSIONING OF UPS FOR GEOTHERMAL
DEVELOPMENT DIVISION**

Kenya Electricity Generating Company Limited
Stima Plaza Phase III, Kolobot Road, Parklands
P.O. BOX 47936-00100
NAIROBI.

Website: www.kengen.co.ke

April, 2017

TABLE OF CONTENTS

		PAGE
SECTION I	INVITATION TO TENDER.....	3
SECTION II	INSTRUCTIONS TO TENDERERS.....	4
	Appendix to Instructions to Tenderers	18
SECTION III	GENERAL CONDITIONS OF CONTRACT.....	20
SECTION IV	SPECIAL CONDITIONS OF CONTRACT.....	27
SECTION V	TECHNICAL SPECIFICATIONS.....	28
SECTION VI	SCHEDULE OF REQUIREMENTS.....	49
SECTION VII	PRICE SCHEDULE FOR GOODS.....	50
SECTION VIII	STANDARD FORMS.....	52

SECTION I INVITATION TO TENDER

The Company invites sealed tenders from eligible candidates for the **Tender for Supply, Installation, Testing and Commissioning of UPS** whose specifications are detailed in the Tender Document.

Interested eligible candidates may obtain further information from and inspect the Tender Documents during official working hours starting at the date of advert at the office of:

Supply Chain Director
Tel: (254) (020) 3666000
Email: tenders@kengen.co.ke; jgesaka@kengen.co.ke;

where the tender document may be collected upon payment of a non-refundable fee of **KShs.1,000.00** paid in cash or through a bankers cheque at any KenGen finance office. The document can also be viewed and downloaded from the website www.kengen.co.ke and www.suppliers.treasury.go.ke. Bidders who download the tender document from the website **are advised to forward their particulars to facilitate any subsequent tender clarifications and addenda**. Downloaded copies are free of charge.

Bidders are advised from time to time to be checking the website for any uploaded further information on this tender. They are also advised to be keen on the information provided in the appendix to Instructions to tenderers (I.T.T.) and the special conditions of the contract (S.C.C.). Unless otherwise stated, tenders **MUST** be accompanied by a security in the format and amount specified in the tender documents and must be submitted in a plain sealed envelope and marked “**Tender for Supply, Installation, Testing and Commissioning of UPS**” and addressed to:

**Company Secretary & Legal Affairs Director
Kenya Electricity Generating Company Limited
10th Floor, KenGen Pension Plaza II
Kolobot Road, Parklands
P O Box 47936 - 00100
NAIROBI, KENYA**

On or before: **29th May 2017 at 10.00AM**

There will be a **Mandatory** site visit on-**11th May 2017 at 10.00am** at Geothermal Complex-Naivasha.

Tenders will be opened on **29th May 2017 at 10.30AM** in the presence of the candidates’ representatives who choose to attend at Stima Plaza III, Executive Committee Room, 7th Floor. The company reserves the right to vary the quantities.

*KenGen adheres to high standards of integrity in its business operations.
Report any unethical behavior immediately to any of the provided anonymous hotline service.*

- 1) *Call Toll Free: 0800722626*
- 2) *Free-Fax: 00800 007788*
- 3) *Email: kengen@tip-offs.com*
- 4) *Website : www.tip-offs.com*

SUPPLY CHAIN DIRECTOR

SECTION II

INSTRUCTIONS TO TENDERERS

2.1 Eligible Tenderers

- 2.1.1 This Invitation for Tenders is open to all tenderers eligible as described in the Invitation to Tender. Successful tenderers shall complete the supply of goods by the intended completion date specified in the Schedule of Requirements (Section VI).
- 2.1.2 The procuring entity's employees, committee members, board members and their relative (spouse and children) are not eligible to participate in the tender.
- 2.1.3 Tenderers shall provide the qualification information statement that the tenderer (including all members of a joint venture and subcontractors) is not associated, or have been associated in the past, directly or indirectly, with a firm or any of its affiliates which have been engaged by the Procuring entity to provide consulting services for the preparation of the design, specifications, and other documents to be used for the procurement of the goods under this Invitation for tenders.
- 2.1.4 Tenderers shall not be under a declaration of ineligibility for corrupt and fraudulent practices.

2.2 Eligible Goods

- 2.2.1 All goods to be supplied under the contract shall have their origin in eligible source countries.
- 2.2.2 For purposes of this clause, "origin" means the place where the goods are mined, grown, or produced. Goods are produced when, through manufacturing, processing, or substantial and major assembly of components, a commercially-recognized product results that is substantially different in basic characteristics or in purpose or utility from its components
- 2.2.3 The origin of goods is distinct from the nationality of the tenderer.

2.3 Cost of Tendering

- 2.3.1 The Tenderer shall bear all costs associated with the preparation and submission of its tender, and the procuring entity, will in no case be

responsible or liable for those costs, regardless of the conduct or outcome of the tendering process.

2.3.2 The price to be charged for the tender document collected from the Procuring Entity shall not exceed Kshs.1,000/= . Downloaded copies are free of charge.

2.3.3 All firms found capable of performing the contract satisfactorily in accordance with the set prequalification criteria shall be prequalified.

2.4. The Tender Document

2.4.1 The tender document comprises the documents listed below and addenda issued in accordance with clause 2.6 of these instructions to Tenderers

- (i) Invitation to Tender
- (ii) Instructions to tenderers
- (iii) General Conditions of Contract
- (iv) Special Conditions of Contract
- (v) Schedule of requirements
- (vi) Technical Specifications
- (vii) Tender Form and Price Schedules
- (viii) Tender Security Form
- (ix) Contract Form
- (x) Performance Security Form
- (xi) Manufacturer's Authorization Form
- (xii) Confidential Business Questionnaire

2.4.2 The Tenderer is expected to examine all instructions, forms, terms, and specifications in the tender documents. Failure to furnish all information required by the tender documents or to submit a tender not substantially responsive to the tender documents in every respect will be at the tenderers risk and may result in the rejection of its tender.

2.5 Clarification of Documents

2.5.1 A prospective tenderer requiring any clarification of the tender document may notify the Procuring entity in writing or by post at the entity's address indicated in the Invitation to Tender. The Procuring entity will respond in writing to any request for clarification of the tender documents, which it receives not later than **seven (7) days prior to the deadline for the submission of tenders**, prescribed by the procuring entity. Written copies of the Procuring entities response (including an explanation of the query but without identifying the source of inquiry) will be sent to all prospective tenderers that have

received the tender document.

2.5.2 The procuring entity shall reply to any clarifications sought by the tenderer **within 3 days** of receiving the request to enable the tenderer to make timely submission of its tender.

2.6 **Amendment of Documents**

2.6.1 **At any time prior** to the deadline for submission of tenders, the Procuring entity, for any reason, whether at its own initiative or in response to a clarification requested by a prospective tenderer, may modify the tender documents by amendment.

2.6.2 All prospective candidates that have received the tender documents will be notified of the amendment in email and will be binding on them.

2.6.3 In order to allow prospective tenderers reasonable time in which to take the amendment into account in preparing their tenders, the Procuring entity, at its discretion, may extend the deadline for the submission of tenders.

2.7 **Language of Tender**

2.7.1 The tender prepared by the tenderer, as well as all correspondence and documents relating to the tender exchange by the tenderer and the Procuring entity, shall be written in English language, provided that any printed literature furnished by the tenderer may be written in another language provided they are accompanied by an accurate English translation of the relevant passages in which case, for purposes of interpretation of the tender, the English translation shall govern.

2.8 **Documents Comprising of Tender**

2.8.1 The tender prepared by the tenderers shall comprise the following components:

- (a) a Tender Form and a Price Schedule completed in accordance with paragraph 2.9, 2.10 and 2.11 below
- (b) documentary evidence established in accordance with paragraph 2.1 that the tenderer is eligible to tender and is qualified to perform the contract if its tender is accepted;
- (c) documentary evidence established in accordance with paragraph 2.2 that the goods and ancillary services to be supplied by the tenderer are eligible goods and services and conform to the tender documents; and

(d) tender security furnished in accordance with paragraph 2.14

2.9 Tender Forms

2.9.1 The tenderer shall complete the Tender Form and the appropriate Price Schedule furnished in the tender documents, indicating the goods to be supplied, a brief description of the goods, their country of origin, quantity, and prices.

2.10 Tender Prices

2.10.1 The tenderer shall indicate on the appropriate Price Schedule the unit prices and total tender price of the goods it proposes to supply under the contract

2.10.2 Prices indicated on the Price Schedule shall include all costs including taxes, insurances and delivery to the premises of the entity.

2.10.3 Prices quoted by the tenderer shall be fixed during the Tender's performance of the contract and not subject to variation on any account. A tender submitted with an adjustable price quotation will be treated as non-responsive and will be rejected, pursuant to paragraph 2.22

2.10.4 The validity period of the tender shall be **90 days** after the date of opening of the tender.

2.11 Tender Currencies

2.11.1 Prices shall be quoted in Kenya Shillings unless otherwise specified in the Appendix to Instructions to Tenderers.

2.12 Tenderers Eligibility and Qualifications

2.12.1 Pursuant to paragraph 2.1. the tenderer shall furnish, as part of its Tender, documents establishing the tenderers eligibility to tender and Its qualifications to perform the contract if its tender is accepted.

2.12.2 The documentary evidence of the tenderers eligibility to tender shall establish to the Procuring entity's satisfaction that the tenderer, at the time of submission of its tender, is from an eligible source country as defined under paragraph 2.1

2.12.3 The documentary evidence of the tenderers qualifications to perform the contract if its tender is accepted shall be established to the Procuring entity's satisfaction;

- (a) that, in the case of a tenderer offering to supply goods under the contract which the tenderer did not manufacture or otherwise produce, the tenderer has been duly authorized by the goods' Manufacturer or producer to supply the goods.
- (b) that the tenderer has the financial, technical, and production capability necessary to perform the contract;
- (c) that, in the case of a tenderer not doing business within Kenya, the tenderer is or will be (if awarded the contract) represented by an Agent in Kenya equipped, and able to carry out the Tenderer's maintenance, repair, and spare parts-stocking obligations prescribed in the Conditions of Contract and/or Technical Specifications.

2.13 Goods Eligibility and Conformity to Tender Documents

2.13.1 Pursuant to paragraph 2.2 of this section, the tenderer shall furnish, as part of its tender documents establishing the eligibility and conformity to the tender documents of all goods which the tenderer proposes to supply under the contract

2.13.2 The documentary evidence of the eligibility of the goods shall consist of a statement in the Price Schedule of the country of origin of the goods and services offered which shall be confirmed by a certificate of origin issued at the time of shipment.

2.13.3 The documentary evidence of conformity of the goods to the tender documents may be in the form of literature, drawings, and data, and shall consist of:

- (a) a detailed description of the essential technical and performance characteristic of the goods;
- (b) a list giving full particulars, including available source and current prices of spare parts, special tools, etc., necessary for the proper and continuing functioning of the goods for a period of two (2) years, following commencement of the use of the goods by the Procuring entity (*if applicable*); and
- (c) a clause-by-clause commentary on the Procuring entity's Technical Specifications demonstrating substantial responsiveness of the goods and service to those specifications, or a statement of deviations and exceptions to the provisions of the Technical Specifications.

2.13.4 For purposes of the documentary evidence to be furnished pursuant to paragraph 2.13.3(c) above, the tenderer shall note that standards for

workmanship, material, and equipment, as well as references to brand names or catalogue numbers designated by the Procurement entity in its Technical Specifications, are intended to be descriptive only and not restrictive. The tenderer may substitute alternative standards, brand names, and/or catalogue numbers in its tender, provided that it demonstrates to the Procurement entity's satisfaction that the substitutions ensure substantial equivalence to those designated in the Technical Specifications.

2.14 Tender Security

2.14.1 The tenderer shall furnish, as part of its tender, a tender security for the amount specified in the Appendix to Invitation to Tenderers.

2.14.2 The tender security shall be in the amount of *(Specify the amount)*.

2.14.3 The tender security is required to protect the Procuring entity against the risk of Tenderer's conduct which would warrant the security's forfeiture, pursuant to paragraph 2.14.7

2.14.4 The tender security shall be denominated in Kenya Shillings or in another freely convertible currency, and shall be in the form of an on-demand bank guarantee issued by a reputable bank located in Kenya or where the bank is located abroad, it must have a local correspondent bank.

The Tender Security may also be in the form of an on-demand guarantee issued by a reputable insurance company approved by the Authority and in the form provided in the tender documents or another form acceptable to the Procuring entity.

The tender security must be valid for at least thirty (30) days beyond the validity of the tender.

2.14.5 Any tender not secured in accordance with paragraph 2.14.1 and 2.14.3 will be rejected by the Procuring entity as non-responsive, pursuant to paragraph 2.22

2.14.6 Unsuccessful Tenderer's tender security will be discharged or returned as promptly as possible, but not later than thirty (30) days after the expiration of the period of tender validity prescribed by the Procuring entity.

2.14.7 The successful Tenderer's tender security will be discharged upon the tenderer signing the contract, pursuant to paragraph 2.27 and furnishing the performance security, pursuant to paragraph 2.28

2.14.8 The tender security may be forfeited:

- (a) if a tenderer withdraws its tender during the period of tender validity specified by the procuring entity on the Tender Form; or
- (b) in the case of a successful tenderer, if the tenderer fails:
 - (i) to sign the contract in accordance with paragraph 2.27
or
 - (ii) to furnish performance security in accordance with paragraph 2.28

2.15 Validity of Tenders

2.15.1 Tenders shall remain valid for **90 days after** the date of tender opening prescribed by the Procuring entity, pursuant to paragraph 2.18. A tender valid for a shorter period shall be rejected by the Procuring entity as non responsive.

2.15.2 In exceptional circumstances, the Procuring entity may solicit the Tenderer's consent to an extension of the period of validity. The request and the responses thereto shall be made in writing. The tender security provided under paragraph 2.14 shall also be suitably extended. A tenderer may refuse the request without forfeiting its tender security. A tenderer granting the request will not be required nor permitted to modify its tender.

2.16 Format and Signing of Tender

2.16.1 The Tenderer shall prepare **two copies of the tender**, clearly marking each "**ORIGINAL TENDER**" and "**COPY OF TENDER**," as appropriate. In the event of any discrepancy between them, the original shall govern.

2.16.2 The original and all copies of the tender shall be typed or written in indelible ink and shall be signed by the tenderer or a person or persons duly authorized to bind the tenderer to the contract. **The latter authorization shall be indicated by written power-of-attorney accompanying the tender. All pages of the tender, except for un-**

amended printed literature, **shall be initialed by the person or persons signing the tender.**

2.16.3 The tender shall have no interlineations, erasures, or overwriting except as necessary to correct errors made by the tenderer, in which case such corrections shall be initialed by the person or persons signing the tender.

2.17 Sealing and Marking of Tenders

2.17.1 The Tenderer shall seal the original and each copy of the tender in separate envelopes, duly marking the envelopes as “ORIGINAL” and “COPY.” The envelopes shall then be sealed in an outer envelope.

2.17.2 The inner and outer envelopes shall:

(a) be addressed to the Procuring entity at the address given in the Invitation to Tender:

(b) bear, tender number and name in the Invitation for Tenders and the words, “DO NOT OPEN BEFORE, **29th May 2017 at 10.00AM**”

2.17.3 The inner envelopes shall also indicate the name and address of the tenderer to enable the tender to be returned unopened in case it is declared “late”.

2.17.4 If the outer envelope is not sealed and marked as required by paragraph 2.17.2, the Procuring entity will assume no responsibility for the tender’s misplacement or premature opening.

2.18 Deadline for Submission of Tenders

2.18.1 Tenders must be received by the Procuring entity at the address specified under paragraph 2.17.2 no later than **29th May 2017 at 10.00AM.**

2.18.2 The Procuring entity may, at its discretion, extend this deadline for the submission of tenders by amending the tender documents in accordance with paragraph 2.6, in which case all rights and obligations of the Procuring entity and candidates previously subject to the deadline will therefore be subject to the deadline as extended

2.19 Modification and Withdrawal of Tenders

2.19.1 The tenderer may modify or withdraw its tender after the tender’s submission, provided that written notice of the modification, including substitution or withdrawal of the tenders, is received by the Procuring Entity prior to the deadline prescribed for submission of tenders.

2.19.2 The Tenderer's modification or withdrawal notice shall be prepared, sealed, marked, and dispatched in accordance with the provisions of paragraph 2.17. A withdrawal notice may also be sent by cable, telex but followed by a signed confirmation copy, postmarked not later than the deadline for submission of tenders.

2.19.3 No tender may be modified after the deadline for submission of tenders.

2.19.4 No tender may be withdrawn in the interval between the deadline for submission of tenders and the expiration of the period of tender validity specified by the tenderer on the Tender Form. Withdrawal of a tender during this interval may result in the Tenderer's forfeiture of its tender security, pursuant to paragraph 2.14.7

2.19.5 The procuring entity may at any time terminate procurement proceedings before contract award and shall not be liable to any person for the termination.

2.19.6 The procuring entity shall give prompt notice of the termination to the tenderers and on request give its reasons for termination within 14 days of receiving the request from any tenderer.

2.20 Opening of Tenders

2.20.1 The Procuring entity will open all tenders in the presence of tenderers' representatives who choose to attend, at 29th May 2017 at 10.30AM and in the location specified in the Invitation to Tender.

The tenderers' representatives who are present shall sign a register evidencing their attendance.

2.20.2 The tenderers' names, tender modifications or withdrawals, tender prices, discounts and the presence or absence of requisite tender security and such other details as the Procuring entity, at its discretion, may consider appropriate, will be announced at the opening.

2.20.3 The Procuring entity will prepare minutes of the tender opening.

2.21 Clarification of Tenders

2.21.1 To assist in the examination, evaluation and comparison of tenders the Procuring entity may, at its discretion, ask the tenderer for a clarification of its tender. The request for clarification and the response shall be in

writing, and no change in the prices or substance of the tender shall be sought, offered, or permitted.

2.21.2 Any effort by the tenderer to influence the Procuring entity in the Procuring entity's tender evaluation, tender comparison or contract award decisions may result in the rejection of the tenderers' tender.

2.22 Preliminary Examination

2.22.1 The Procuring entity will examine the tenders to determine whether they are complete, whether any computational errors have been made, whether required sureties have been furnished, whether the documents have been properly signed, and whether the tenders are generally in order.

2.22.2 Arithmetical errors will be rectified on the following basis. If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantify, the unit price shall prevail, and the total price shall be corrected. If the candidate does not accept the correction of the errors, its tender will be rejected, and its tender security forfeited. If there is a discrepancy between words and figures the amount in words will prevail

2.22.3 The Procuring entity may waive any minor informality or non-conformity or irregularity in a tender which does not constitute a material deviation, provided such waiver does not prejudice or affect the relative ranking of any tenderer.

2.22.4 Prior to the detailed evaluation, pursuant to paragraph 2.23 the Procuring entity will determine the substantial responsiveness of each tender to the tender documents. For purposes of these paragraphs, a substantially responsive tender is one, which conforms to all the terms and conditions of the tender documents without material deviations. The Procuring entity's determination of a tender's responsiveness is to be based on the contents of the tender itself without recourse to extrinsic evidence.

2.22.5 If a tender is not substantially responsive, it will be rejected by the Procuring entity and may not subsequently be made responsive by the tenderer by correction of the non-conformity.

2.23 Conversion to Single Currency

2.23.1 Where other currencies are used, the procuring entity will convert these currencies to Kenya Shillings using the selling exchange rate on the date of tender closing provided by the Central Bank of Kenya.

2.24 Evaluation and Comparison of Tenders

2.24.1 The Procuring entity will evaluate and compare the tenders which have been determined to be substantially responsive, pursuant to paragraph 2.22

2.24.2 The tender evaluation committee shall evaluate the tender within 30 days of the validity period from the date of opening the tender.

2.24.3 A tenderer who gives false information in the tender document about its qualification or who refuses to enter into a contract after notification of contract award shall be considered for debarment from participating in future public procurement.

2.25 Preference

2.25.1 Preference where allowed in the evaluation of tenders shall not exceed 15%

2.26 Contacting the Procuring entity

2.26.1 Subject to paragraph 2.21 no tenderer shall contact the Procuring entity on any matter related to its tender, from the time of the tender opening to the time the contract is awarded.

2.26.2 Any effort by a tenderer to influence the Procuring entity in its decisions on tender, evaluation, tender comparison, or contract award may result in the rejection of the Tenderer's tender.

2.27 Award of Contract

(a) Post-qualification

2.27.1 In the absence of pre-qualification, the Procuring entity will determine to its satisfaction whether the tenderer that is selected as having submitted the lowest evaluated responsive tender is qualified to perform the contract satisfactorily.

2.27.2 The determination will take into account the tenderer financial, technical, and production capabilities. It will be based upon an examination of the documentary evidence of the tenderers qualifications

submitted by the tenderer, pursuant to paragraph 2.12.3 as well as such other information as the Procuring entity deems necessary and appropriate.

2.27.3 A positive determination will be a prerequisite for award of the contract to the tenderer. A negative determination will result in rejection of the Tenderer's tender, in which event the Procuring entity will proceed to the next lowest evaluated tender to make a similar determination of that Tenderer's capabilities to perform satisfactorily.

(b) **Award Criteria**

2.27.4 The Procuring entity will award the contract to the successful tenderer(s) whose tender has been determined to be substantially responsive and has been determined to be the lowest evaluated tender, provided further that the tenderer is determined to be qualified to perform the contract satisfactorily.

(c) **Procuring entity's Right to Vary quantities**

2.27.5 The Procuring entity reserves the right at the time of contract award to increase or decrease the quantity of goods originally specified in the Schedule of requirements without any change in unit price or other terms and conditions

(d) **Procuring entity's Right to accept or Reject any or All Tenders**

2.27.6 The Procuring entity reserves the right to accept or reject any tender, and to annul the tendering process and reject all tenders at any time prior to contract award, without thereby incurring any liability to the affected tenderer or tenderers or any obligation to inform the affected tenderer or tenderers of the grounds for the Procuring entity's action

2.28 Notification of Award

2.28.1 Prior to the expiration of the period of tender validity, the Procuring entity will notify the successful tenderer in writing that its tender has been accepted.

2.28.2 The notification of award will constitute the formation of the Contract but will have to wait until the contract is finally signed by both parties

2.28.3 Upon the successful Tenderer's furnishing of the performance security pursuant to paragraph 2.28, the Procuring entity will promptly notify

each unsuccessful Tenderer and will discharge its tender security, pursuant to paragraph 2.14

2.29 Signing of Contract

2.29.1 At the same time as the Procuring entity notifies the successful tenderer that its tender has been accepted, the Procuring entity will send the tenderer the Contract Form provided in the tender documents, incorporating all agreements between the parties.

2.29.2 The parties to the contract shall have it signed within **fifteen (15) days** from the date of notification of contract award unless there is an administrative review request.

2.29.3 Within **fifteen (15) days** of receipt of the Contract Form, the successful tenderer shall sign and date the contract and return it to the Procuring entity.

2.30 Performance Security

2.30.1 Within **fifteen (15) days** of the receipt of notification of award from the Procuring entity, the successful tenderer shall furnish the performance security in accordance with the Conditions of Contract, in the Performance Security Form provided in the tender documents, or in another form acceptable to the Procuring entity.

2.30.2 Failure of the successful tenderer to comply with the requirements of paragraph 2.27 or paragraph 2.28 shall constitute sufficient grounds for the annulment of the award and forfeiture of the tender security, in which event the Procuring entity may make the award to the next lowest evaluated Candidate or call for new tenders.

2.31 Corrupt or Fraudulent Practices

2.31.1 The Procuring entity requires that tenderers observe the highest standard of ethics during the procurement process and execution of contracts when used in the present regulations, the following terms are defined as follows;

(i) “corrupt practice” means the offering, giving, receiving, or soliciting of anything of value to influence the action of a public official in the procurement process or in contract execution; and

(ii) “fraudulent practice” means a misrepresentation of facts in order to influence a procurement process or the execution of a contract

to the detriment of the Procuring entity, and includes collusive practice among tenderer (prior to or after tender submission) designed to establish tender prices at artificial non-competitive levels and to deprive the Procuring entity of the benefits of free and open competition;

2.31.2 The procuring entity will reject a proposal for award if it determines that the tenderer recommended for award has engaged in corrupt or fraudulent practices in competing for the contract in question.

2.31.3 Further a tenderer who is found to have indulged in corrupt or fraudulent practices risks being debarred from participating in public procurement in Kenya.

Appendix to Instructions to Tenderers

The following information regarding the particulars of the tender shall complement supplement or amend the provisions of the instructions to tenderers. Wherever there is a conflict between the provision of the instructions to tenderers and the provisions of the appendix, the provisions of the appendix herein shall prevail over those of the instructions to tenderers

INSTRUCTIONS TO TENDERERS REFERENCE	PARTICULARS OF APPENDIX TO INSTRUCTIONS TO TENDERS
2.1.5	This Invitation for Tenders is open to all tenderers eligible as described in the Invitation to Tender.
2.10.2	For local suppliers, tender prices shall be Delivered and Duty Paid (DDP) to Olkaria.
2.10.4	The validity period of the tender shall be 90 days <u>after</u> the date of opening of the tender.
2.14.2	The tender security shall be in the amount of Kenya Shillings Two Hundred Thousand (Kshs. 200,000.00) or equivalent in a freely convertible currency.
2.14.4	The tender security must be valid for at least thirty (30) days beyond the validity of the tender.
2.16.1	The Tenderer shall prepare two copies of the tender , clearly marking each “ ORIGINAL TENDER ” and “ COPY OF TENDER ”.
2.18.1	<p>Tender closing date: 29th May 2017 at 10.00AM</p> <p>Tender Opening date: 29th May 2017 at 10.30AM</p> <p>There will be a Mandatory site visit on-11th May 2017 at 10.00am at Geothermal Complex-Naivasha.</p>
2.22.2	No correction of errors. The tender sum as submitted and read out during the tender opening shall be absolute and final and shall not be the subject of correction, adjustment or amendment in any way by any person or entity.
2.24.1	<p><i>The following shall be the evaluation Criteria</i></p> <p>A) Mandatory preliminary evaluation criteria:</p> <ul style="list-style-type: none"> • Duly completed tender form. • Duly completed price schedules. • Manufacturer’s authorization letter. • Audited financial statements for the past two (2) years (2013-2015). • Valid business permit. • Valid Tax Compliance Certificate issued by Kenya Revenue Authority • Copy of Certificate of Incorporation/ Registration.

	<ul style="list-style-type: none"> • Duly filled and signed Mandatory Confidential Business Questionnaire. • Tender validity period of 90 days after the date of opening of the tender. • The tender security amount of Kenya Shillings Two Hundred Thousand (KShs. 200,000.00) or equivalent in a freely convertible currency. • Tender Security validity of 120 days from the date of tender closing. • Sequential pagination/serialization of all pages in the tender document. • Tenderer must quote for all items in the schedule to be considered responsive. • The delivery and completion period shall be within <u>2 Months</u> after receipt of the purchase order. • Site Visit certificate <p><i>B) Technical Evaluation criteria:(shall be evaluated on pass or fail system)</i></p> <ul style="list-style-type: none"> • Compliance to the technical specifications. • Documentary evidence to prove that the equipment offered comply with the Technical Specifications must be provided. • Warranty/Guarantee period must be at least 12 months. • Evidence of the product conformity to international standards for the product and safety. • Conformity of all the items to all the required technical specifications. • Warranty/Guarantee period must be at least 12 months. <p><i>C)Financial Evaluation criteria:</i></p> <ul style="list-style-type: none"> • Award shall be based on the total lowest evaluated bidder.
2.27.7	<i>KenGen may at its own discretion conduct due diligence on the eligible bidders to establish their ability to perform the contract.</i>
2.31	<p><i>KenGen adheres to high standards of integrity in its business operations.</i></p> <p><i>Report any unethical behavior immediately to any of the provided anonymous hotline service.</i></p> <p><i>5) Call Toll Free: 0800722626</i></p> <p><i>6) Free-Fax: 00800 007788</i></p> <p><i>7) Email: kengen@tip-offs.com</i></p> <p><i>8) Website : www.tip-offs.com</i></p>

SECTION III:

GENERAL CONDITIONS OF CONTRACT

3.1 Definitions

3.1.1 In this Contract, the following terms shall be interpreted as indicated:-

- (a) “The Contract” means the agreement entered into between the Procuring entity and the tenderer, as recorded in the Contract Form signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.
- (b) “The Contract Price” means the price payable to the tenderer under the Contract for the full and proper performance of its contractual obligations
- (c) “The Goods” means all of the equipment, machinery, and/or other materials, which the tenderer is required to supply to the Procuring entity under the Contract.
- (d) “The Procuring entity” means the organization purchasing the Goods under this Contract.
- (e) “The Tenderer” means the individual or firm supplying the Goods under this Contract.

3.2 Application

3.2.1 These General Conditions shall apply in all Contracts made by the Procuring entity for the procurement installation and commissioning of equipment

3.3 Country of Origin

3.3.1 For purposes of this clause, “Origin” means the place where the Goods were mined, grown or produced.

3.3.2 The origin of Goods and Services is distinct from the nationality of the tenderer.

3.4 Standards

3.4.1 The Goods supplied under this Contract shall conform to the standards mentioned in the Technical Specifications.

3.5 Use of Contract Documents and Information

3.5.1 The tenderer shall not, without the Procuring entity's prior written consent, disclose the Contract, or any provision therefore, or any specification, plan, drawing, pattern, sample, or information furnished by or on behalf of the Procuring entity in connection therewith, to any person other than a person employed by the tenderer in the performance of the Contract.

3.5.2 The tenderer shall not, without the Procuring entity's prior written consent, make use of any document or information enumerated in paragraph 3.5.1 above

3.5.3 Any document, other than the Contract itself, enumerated in paragraph 3.5.1 shall remain the property of the Procuring entity and shall be returned (all copies) to the Procuring entity on completion of the Tenderer's performance under the Contract if so required by the Procuring entity

3.6 Patent Rights

3.6.1 The tenderer shall indemnify the Procuring entity against all third-party claims of infringement of patent, trademark, or industrial design rights arising from use of the Goods or any part thereof in the Procuring entity's country

3.7 Performance Security

3.7.1 Within **fifteen (15) days** of receipt of the notification of Contract award, the successful tenderer shall furnish to the Procuring entity the performance security in the amount specified in Special Conditions of Contract.

3.7.2 The proceeds of the performance security shall be payable to the Procuring entity as compensation for any loss resulting from the Tenderer's failure to complete its obligations under the Contract.

3.7.3 The performance security shall be denominated in the currency of the Contract, or in a freely convertible currency acceptable to the Procuring entity and shall be in the form of a bank guarantee or an irrevocable letter

of credit issued by a reputable bank located in Kenya or abroad, acceptable to the Procuring entity, in the form provided in the tender documents.

- 3.7.4 The performance security will be discharged by the Procuring entity and returned to the Candidate not later than thirty (30) days following the date of completion of the Tenderer's performance obligations under the Contract, including any warranty obligations, under the Contract

3.8 Inspection and Tests

- 3.8.1 The Procuring entity or its representative shall have the right to inspect and/or to test the goods to confirm their conformity to the Contract specifications. The Procuring entity shall notify the tenderer in writing in a timely manner, of the identity of any representatives retained for these purposes.

- 3.8.2 The inspections and tests may be conducted in the premises of the tenderer or its subcontractor(s), at point of delivery, and/or at the Goods' final destination. If conducted on the premises of the tenderer or its subcontractor(s), all reasonable facilities and assistance, including access to drawings and production data, shall be furnished to the inspectors at no charge to the Procuring entity.

- 3.8.3 Should any inspected or tested goods fail to conform to the Specifications, the Procuring entity may reject the equipment, and the tenderer shall either replace the rejected equipment or make alterations necessary to make specification requirements free of costs to the Procuring entity.

- 3.8.4 The Procuring entity's right to inspect, test and where necessary, reject the goods after the Goods' arrival shall in no way be limited or waived by reason of the equipment having previously been inspected, tested and passed by the Procuring entity or its representative prior to the equipment delivery.

- 3.8.5 Nothing in paragraph 3.8 shall in any way release the tenderer from any warranty or other obligations under this Contract.

3.9 Packing

- 3.9.1 The tenderer shall provide such packing of the Goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in the Contract.

3.9.2 The packing, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the Contract

3.10 Delivery and Documents

3.10.1 Delivery of the Goods shall be made by the tenderer in accordance with the terms specified by Procuring entity in its Schedule of Requirements and the Special Conditions of Contract

3.11 Insurance

3.11.1 The Goods supplied under the Contract shall be fully insured against loss or damage incidental to manufacturer or acquisition, transportation, storage, and delivery in the manner specified in the Special conditions of contract.

3.12 Payment

3.12.1 The method and conditions of payment to be made to the tenderer under this Contract shall be specified in Special Conditions of Contract

3.12.2 Payments shall be made promptly by the Procuring entity as specified in the contract

3.13 Prices

3.13.1 Prices charged by the tenderer for goods delivered and services performed under the Contract shall not, with the exception of any price adjustments authorized in Special Conditions of Contract, vary from the prices by the tenderer in its tender.

3.13.2 Contract price variations shall not be allowed for contracts not exceeding one year (12 months)

3.13.3 Where contract price variation is allowed, the variation shall not exceed 25% of the original contract price.

3.13.4 Price variation request shall be processed by the procuring entity within 30 days of receiving the request.

3.14. Assignment

3.14.1 The tenderer shall not assign, in whole or in part, its obligations to perform under this Contract, except with the Procuring entity's prior written consent

3.15 Subcontracts

3.15.1 The tenderer shall notify the Procuring entity in writing of all subcontracts awarded under this Contract if not already specified in the tender. Such notification, in the original tender or later, shall not relieve the tenderer from any liability or obligation under the Contract

3.16 Termination for default

3.16.1 The Procuring entity may, without prejudice to any other remedy for breach of Contract, by written notice of default sent to the tenderer, terminate this Contract in whole or in part

(a) if the tenderer fails to deliver any or all of the goods within the period(s) specified in the Contract, or within any extension thereof granted by the Procuring entity

(b) if the tenderer fails to perform any other obligation(s) under the Contract

(c) if the tenderer, in the judgment of the Procuring entity has engaged in corrupt or fraudulent practices in competing for or in executing the Contract

3.16.2 In the event the Procuring entity terminates the Contract in whole or in part, it may procure, upon such terms and in such manner as it deems appropriate, equipment similar to those undelivered, and the tenderer shall be liable to the Procuring entity for any excess costs for such similar goods.

3.17 Liquidated Damages

3.17.1. If the tenderer fails to deliver any or all of the goods within the period(s) specified in the contract, the procuring entity shall, without prejudice to its other remedies under the contract, deduct from the contract prices liquidated damages sum equivalent to 0.5% of the delivered price of the delayed items up to a maximum deduction of 10% of the delayed goods. After this the tenderer may consider termination of the contract.

3.18 Resolution of Disputes

3.18.1 The procuring entity and the tenderer shall make every effort to resolve amicably by direct informal negotiation and disagreement or dispute arising between them under or in connection with the contract

3.18.2 If, after thirty (30) days from the commencement of such informal negotiations both parties have been unable to resolve amicably a contract dispute, either party may require adjudication in an agreed national or international forum, and/or international arbitration.

3.19 Language and Law

3.19.1 The language of the contract and the law governing the contract shall be English language and the Laws of Kenya respectively unless otherwise stated.

3.20 Force Majeure

3.20.1 The tenderer shall not be liable for forfeiture of its performance security or termination for default if and to the extent that it's delay in performance or other failure to perform its obligations under the Contract is the result of an event of Force Majeure.

3.21 Taxes

3.21.1 "**Taxes**" means all present and future taxes, levies, duties, charges, assessments, deductions or withholdings whatsoever, including any interest thereon, and any penalties and fines with respect thereto, wherever imposed, levied, collected, or withheld pursuant to any regulation having the force of law and "Taxation" shall be construed accordingly.

3.21.2 Local Taxation

Nothing in the Contract shall relieve the Contractor and/or his Sub-Contractors from their responsibility to pay any taxes, statutory contributions and levies that may be levied on them in Kenya in respect of the Contract. The Contract Price shall include all applicable taxes and shall not be adjusted for any of these taxes.

3.21.3 The Contractor shall be deemed to be familiar with the tax laws in the Employer's Country and satisfied themselves with the requirements for all taxes, statutory contributions and duties to which they may be subjected during the term of the Contract.

3.21.4 In instances where discussions are held between the Employer and the Contractor regarding tax matters, this shall not be deemed to constitute competent advice and hence does not absolve the

Contractor of their responsibility in relation to due diligence on the tax issue as per 3.21.2 above.

Tax Deduction

3.21.5 If the Employer is required to make a tax deduction by Law, then the deduction shall be made from payments due to the Contractor and paid directly to the Kenya Revenue Authority. The Employer shall upon remitting the tax to Kenya Revenue Authority furnish the Contractor with the relevant tax deduction certificates.

3.21.6 Where the Contractor is paid directly by the Financiers and the Employer is not able to deduct tax, then the Contractor will be required to pay the tax deduction to Kenya Revenue Authority in the name of the Employer and furnish the Employer with an original receipt thereof as evidence of such payment. In absence of the said evidence, the Employer will not process any subsequent payments to the Contractor.

Tax Indemnity

3.21.7 The Contractor shall indemnify and hold the Employer harmless from and against any and all liabilities, which the Employer may incur for any reason of failure by the Contractor to comply with any tax laws arising from the execution of the Contract whether during the term of the Contract or after its expiry.

3.21.8 The Contractor warrants to pay the Employer (within fourteen (14) days of demand by the Employer), an amount equal to the loss, liability or cost which the Employer determines has been (directly or indirectly) suffered by the Employer for or on account of the Contractor's Tax liability arising from the Contract.

3.21.9 Where the amount in 3.21.8 above remains unpaid after the end of the fourteen (14) days moratorium, the Employer shall be entitled to compensation for financing charges.

SECTION IV

SPECIAL CONDITIONS OF CONTRACT

- 4.1. Special Conditions of Contract shall supplement the General Conditions of Contract. Whenever there is a conflict, between the GCC and the SCC, the provisions of the SCC herein shall prevail over these in the GCC.
42. Special conditions of contract as relates to the GCC

REFERENCE OF GCC	SPECIAL CONDITIONS OF CONTRACT
3.7.1	Performance security; <ul style="list-style-type: none">The Performance Security shall be in the amount of 10% of the Contract Price
3.8.1	Inspection and tests <ul style="list-style-type: none">All consignments subject to Pre-Export Verification of Conformity (PVoC) to Standards Programme must obtain a Certificate of Conformity (CoC) issued by PvoC Country Offices Prior to shipment. The Certificate is a mandatory Customs Clearance document in Kenya; Consignments arriving at Kenyan Ports without this document will be denied entry into the Country. Since PVoC is a conformity assessment process to verify that products imported to Kenya are in compliance with the applicable Kenya standards or approved equivalents, regulations and technical requirements before shipment, it is the sole responsibility of the supplier (i.e. exporter) to demonstrate the same and hence meet any associated costs of verification.
3.10.1	Delivery period; <ul style="list-style-type: none">The Goods shall be delivered within 2 months from the date of contract award i.e. date of receipt of official order or signed contract
3.12.1	Payment terms; <p>KenGen's payment terms are 30 days upon receipt of certified invoices and delivery notes confirming that the invoiced material has been delivered and is in accordance with the contract.</p> <p>Payment shall be made through KenGen's cheque or telegraphic transfer for the amount of contract. The terms shall be strictly Delivered and Duty Paid (DDP) to Olkaria.</p> Advance Payment <ul style="list-style-type: none">Advance payment is not applicable.
3.13.1	Prices; <ul style="list-style-type: none">Prices shall be fixed during the Supplier's performance of the Contract and not subject to variation on any account
3.18.1	<i>Arbitration where necessary shall be by the Chartered Institute of Arbitrators Kenya Chapter or other International body.</i>

SECTION V

TECHNICAL SPECIFICATIONS

Manufacturer's Authorization, Warranty, Product Brochure/Technical Datasheet are mandatory requirements and shall form part of the evaluation criteria.

ICT Geothermal has data centers that host critical ICT equipment. These data centers require dedicated power supply to ensure that there is minimal power interruptions. Currently there is an existing mains electricity and a standby generator which comes up when there is failure with the mains electricity. To have a dedicated power supply to the equipment in the data center, Online UPS systems that gives stable power when there are power interruptions is recommended. Uninterrupted power supply to the equipment at the data centers reduces the sites downtime hence improvement in ICT systems availability.

The ups systems should have:

- A modular system –When there is a need to increase power consumption there is no need to purchase a new UPS. Instead, user needs to simply add additional modules as needed, thus ensuring maximum flexibility. This also creates the ability to replace non-working modules without having to replace the entire system.
- High power output small footprint.
- High levels of electrical efficiency > 96%.
- Advanced technological systems manufactured according to the strictest international standards
- Easy to use and operate.

The ups system should be:

Online UPS

True double conversion On-line UPS systems that connects power directly to protected systems. In the event of a power failure, no power transfer switches are necessary. When voltage drops, battery power comes online instantaneously. When power is restored, the UPS reconnects to mains power while charging the system's batteries.

During a power failure, the system should supply electricity for a minimum period of 8 hours from a reservoir of batteries. It is therefore necessary to have an external battery rack to ensure that the load is constantly supplied with power.

3 phase

Because of high kVA consumption and high power density, three phase UPS systems is generally the preferred solution in this case. A three phase UPS not only powers the load but simultaneously compensates for an unbalanced load and regulates output voltage.

Notes Applicable to All Schedules:

1. The equipment to be supplied shall be new, high efficient, unused and of the latest design.
2. Documentary evidence to prove that the equipment offered comply with the Technical Specifications given below **must** be provided.
3. **After Sales Support:** Tenderers shall propose how after sales support (spare parts) and back-up technical services will be provided. A draft SLA should be attached with the bid offer for discussion.
4. **Certificate of Warranty:** A certificate of warranty shall be submitted covering at least **24 months (2 Years)** for the quoted equipment.
5. **Technical Data/Brochures:** - Bidders **must** provide relevant technical data detailing the performance parameters of the equipment or **Original manufacturer brochures**, where there are more than one model on a brochure, the bidder, **Must** highlight the option which they are quoting for in this tender. Material safety data sheets shall be included.
6. As built designs should be provided after the installations work.
7. All items in each schedule **must** be quoted for the bid to be considered responsive.
8. The client has the discretion of awarding each schedule separately.
9. There will be a mandatory Site visit.
10. Capacity/discharge/load testing on the batteries will be carried out by the contractor during commissioning to meet the set minimum specifications.

TECHNICAL SPECIFICATIONS FOR 40KVA/32KW UPS WITH EXTERNAL BATTERY PACK TO SUPPLY POWER FOR 8 HOURS AT OLKARIA PLAZA DATA CENTER

KenGen Specification	Compliance	Bidder's Offer (MUST FILL)
Topology	True on-line, double-conversion, VFI	
Operation	Continuous	
Technology	Double conversion online topology with automatic	

	Bypass switch and maintenance bypass switch.	
INPUT		
Rated Voltage (nominal, Vac)	415 Vac; three phase input, 4 wire (L1, L2, L3, N, G)	
Rated input current	(Maximum Load) 48A/50A/53A	
Input Phase	3-Phase	
Frequency Compatibility	50 Hz	
UPS Input Connection	Hardwire	
Input power factor	> 0.96 (Cos phi 1)	
OUTPUT		
Output kVA Capacity (kVA)	40	
Output Watt Capacity (KW)	32	
Nominal voltage(V)	220~240	
Frequency Compatibility	50 Hz	
Output Voltage Regulation (Line Mode)	+/- 1%	
Output Voltage Regulation (Battery Mode)	+/- 1%	
Output Receptacles	Hardwire	
Output AC Waveform (AC Mode) Sine wave	Sine wave	
Output AC Waveform (Battery Mode)	Pure Sine wave	
Power Factor	0.8	
Crest Factor	3:1	
BATTERIES		
Type	Sealed, lead acid, rechargeable, maintenance-free	
External Battery Pack Battery	Yes	
Voltage	The nominal voltage will be 12 volts per battery. The final voltage for 8-hour discharge rate should be at lowest 11.1 volts.	
Positive Plates	These should be constructed of pure lead to ensure that there is no fall off in capacity throughout their life time.	

Negative plates	The construction of negative plates should be of pasted grid.	
Accessories	<p>Batteries must be supplied complete with the appropriately sized and number of :</p> <ul style="list-style-type: none"> • Interconnecting links • Terminal insulators • Nuts • Bolts • Flat and spring washers. <p>All the above must be factory made and be of suitable type not to be affected by corrosion.</p>	
Maintenance	<p>Internal Adjustments of :</p> <ul style="list-style-type: none"> • Float voltage • Boost voltage • Over voltage shut down • Current limit • Temperature compensation slope • Auto boost to float threshold limit, • Load disconnect voltage(under and over voltage) • Load disconnect hysteresis voltage. 	
Standard Features		

Auto Float/Boost	<p>Rectifier should enter boost mode at power up. When battery current reduces to float threshold limit, unit reverts to float voltage setting.</p> <p>When in boost but out of current limit, rectifier will automatically switch back to float after approximately four hours.</p> <p>If battery current exceeds the float threshold limit when the rectifier is in float mode it will automatically switch to boost mode.</p>	
Alarm and Indicator Controls	<p>Internal Alarm Card for:</p> <ul style="list-style-type: none"> • Rectifier fail • Off • Normal • Float low • Float high • Changeover relay contact for mains fail. <p>Air forced cooling using temperature controlled fans.</p>	
Power factor	Power factor corrected.	
Float/ boost charge	<p>Automatic float/ boost charge cycle.</p> <p>Alarm and control interface with active load sharing.</p> <p>Temperature compensation.</p>	
Indications	AC input voltage, DC Output Voltage, Output current.	

Internal Alarm Card	Internal alarm card with potential free relay outputs. Alarms indications to be provided: <ul style="list-style-type: none"> • AC mains fail • DC Overvoltage, Meters: <ul style="list-style-type: none"> • AC input voltage • DC output ammeter • DC output voltmeter (digital with 1.5% accuracy for all values) 	
Battery protection	Battery voltage discharge prevention device. Low battery cut off.	
Recharge Rate (Included Batteries)	4 hours from 10% to 90%	
Battery Replacement Description	Hot-swappable, replaceable batteries	
Battery Volt-Amp-Hour capacity	8 hours	
REGULATION		
Voltage Regulation Description	Online, double-conversion power conditioning	
Overvoltage Correction	Maintains continuous operation without using battery power during over voltages to 276-477 (3-phase, 4-wire, wye), reducing output within 1% of nominal	
Under voltage Correction	Maintains continuous operation without using battery power during brownout/under voltage conditions to 173-300 (3-phase, 4-wire, wye)	
USER INTERFACE, ALERTS & CONTROLS		

Switches	ON button turns UPS inverter on. OFF button turns UPS inverter off. LCD Display Control Buttons browse through and select items displayed on LCD screen. EPO (Emergency Power Off) button turns UPS output off and disables Bypass output	
Alarm Cancel Operation	Power-fail alarm can be silenced using alarm-cancel switch	
Audible Alarm	Alarms signal a variety of operational conditions: low-battery, overload, shutdown, bypass and more.	
LED Indicators	4-LED Display: Displays normal AC input, on battery power, bypass input and fault conditions	
SURGE / NOISE SUPPRESSION		
EMI / RFI AC Noise Suppression	Yes	
AC Suppression Response Time	Instantaneous	
GENERAL		
Ambient temperature	(°C) -10 to +40 (operating and storage)	
Relative humidity (%)	95 max. (non-condensing)	
Altitude (m)	2000 Masl without derating	
Cooling system	Forced air (multi-fan with speed control)	
COMMUNICATIONS		
Communications Interface	DB9 Serial; Slot for SNMP/Web interface	
Network Management Cards	SNMPWEBCARD; TLNETCARD; WEBCARDLX; MODBUSCARD; RELAYIOCARD	
PowerAlert Software	For local monitoring via the UPS's built-in communication ports	
Communications Cable	DB9 cabling included	

LINE / BATTERY TRANSFER		
Transfer Time	No transfer time (0 ms.) in online, double-conversion mode	
Low Voltage Transfer to Battery Power (Setpoint)	Maintains continuous operation without using battery power during brownout/undervoltage conditions to 173-300V AC (3-phase, 4-wire, wye). Below this point, output is maintained utilizing reserve battery power	
High Voltage Transfer to Battery Power (Setpoint)	Maintains continuous operation without using battery power during overvoltages to 276-477V AC (3-phase, 4-wire, wye), reducing output within 1% of nominal. Above this point, output is maintained utilizing reserve battery power	
SPECIAL FEATURES		
Cold Start (Startup in Battery Mode During a Power Failure)	Cold-start operation supported	
High Availability UPS Features	Automatic inverter bypass; Hot swappable batteries	
LCD DISPLAY		
Input	Voltage, current	
Output	Voltage, frequency, current	
Batteries	Voltage	
Log (events memory)	Last events	
STANDARDS		
Safety	IEC 62040-1	
EMC	IEC 62040-2	
Design	IEC 62040-3	
Low magnetic field radiation	EMF as per ICNIRP	
WARRANTY		
Product Warranty Period	2-year comprehensive warranty and maintenance(Products and parts)	

TECHNICAL SPECIFICATIONS FOR 20KVA/16KW UPS WITH EXTERNAL BATTERY PACK TO SUPPLY POWER FOR 8 HOURS TO OLKARIA II DATA CENTER

KenGen Specification	Compliance	Bidder's Offer (MUST FILL)
Topology	True on-line, double-conversion, VFI	
Operation	Continuous	
Technology	Double conversion online topology with automatic Bypass switch and maintenance bypass switch.	
INPUT		
Rated Voltage (nominal, Vac)	415 Vac; three phase input, 4 wire (L1, L2, L3, N, G)	
Rated input current (Maximum Load)	28A / 29A / 30A	
Input Phase	3-Phase	
Frequency Compatibility	50 Hz	
UPS Input Connection	Hardwire	
Input power factor	> 0.96 (Cos phi 1)	
OUTPUT		
Output kVA Capacity (kVA)	20	
Output Watt Capacity (kW)	16	
Nominal voltage(V)	220~240	
Frequency Compatibility	50 Hz	
Output Voltage Regulation (Line Mode)	+/- 1%	
Output Voltage Regulation (Battery Mode)	+/- 1%	
Output Receptacles	Hardwire	
Output AC Waveform (AC Mode) Sine wave	Sine wave	
Output AC Waveform (Battery Mode)	Pure Sine wave	
Power Factor	0.8	
Crest Factor	3:1	
BATTERIES		
Type	Sealed, lead acid, rechargeable, maintenance-free	
External Battery Pack Battery	Yes	

Voltage	The nominal voltage will be 12 volts per battery. The final voltage for 8-hours discharge rate should be at lowest 11.1 volts.	
Positive Plates	These should be constructed of pure lead to ensure that there is no fall off in capacity throughout their life time.	
Negative plates	The construction of negative plates should be of pasted grid.	
Accessories	Batteries must be supplied complete with the appropriately sized and number of interconnecting links, terminal insulators, nuts, bolts, flat and spring washers. All of which must be of suitable type not to be affected by corrosion.	
Maintenance	Internal Adjustments: Float voltage, Boost voltage, Over voltage shut down, Current limit, Temperature compensation slope, Auto boost to float threshold limit, Load disconnect voltage, Load disconnect hysteresis voltage.	
Standard Features		
Auto Float/Boost	Rectifier enters boost mode at power up. When battery current reduces to float threshold limit, unit reverts to float voltage setting. When in boost but out of current limit, rectifier will automatically switch back to float after approximately four hours.	

	If battery current exceeds the float threshold limit when the rectifier is in float mode it will automatically switch to boost mode.	
Alarm and Indicator Controls	Internal Alarm Card for rectifier fail, off, normal, float low, float high, changeover relay contact for mains fail. Air forced cooling using temperature controlled fans.	
Power factor	Power factor corrected.	
Float/ boost charge	Automatic float/ boost charge cycle. Alarm and control interface with active load sharing. Temperature compensation.	
Indications	AC input voltage, DC Output Voltage, Output current.	
Internal Alarm Card	Internal alarm card with potential free relay outputs. Alarms indications to be provided: AC mains fail, DC Overvoltage, Meters: AC input voltage, DC output ammeter, DC output voltmeter (digital with 1.5% accuracy for all values)	
Battery protection	Battery voltage discharge prevention device Low battery cut off	
Recharge Rate (Included Batteries)	4 hours from 10% to 90%	
Battery Replacement Description	Hot-swappable, replaceable batteries	
Battery Volt-Amp-Hour capacity	8 hours	
REGULATION		

Voltage Regulation Description	Online, double-conversion power conditioning	
Overvoltage Correction	Maintains continuous operation without using battery power during over voltages to 276-477 (3-phase, 4-wire, wye), reducing output within 1% of nominal	
Under voltage Correction	Maintains continuous operation without using battery power during brownout/under voltage conditions to 173-300 (3-phase, 4-wire, wye)	
USER INTERFACE, ALERTS & CONTROLS		
Switches	ON button turns UPS inverter on. OFF button turns UPS inverter off. LCD Display Control Buttons browse through and select items displayed on LCD screen. EPO (Emergency Power Off) button turns UPS output off and disables Bypass output	
Alarm Cancel Operation	Power-fail alarm can be silenced using alarm-cancel switch	
Audible Alarm	Alarms signal a variety of operational conditions: low-battery, overload, shutdown, bypass and more	
LED Indicators	4-LED Display: Displays normal AC input, on battery power, bypass input and fault conditions	
SURGE / NOISE SUPPRESSION		
EMI / RFI AC Noise Suppression	Yes	
AC Suppression Response Time	Instantaneous	
GENERAL		

Ambient temperature	(°C) -10 to +40 (operating and storage)	
Relative humidity (%)	95 max. (non- condensing)	
Altitude (m)	1000 without derating (derating table below)	
Cooling system	Forced air (multi-fan with speed control)	
COMMUNICATIONS		
Communications Interface	DB9 Serial; Slot for SNMP/Web interface	
Network Management Cards	SNMPWEBCARD; TLNETCARD; WEBCARDLX; MODBUSCARD; RELAYIOCARD	
PowerAlert Software	For local monitoring via the UPS's built-in communication ports	
Communications Cable	DB9 cabling included	
LINE / BATTERY TRANSFER		
Transfer Time	No transfer time (0 ms.) in online, double- conversion mode	
Low Voltage Transfer to Battery Power (Setpoint)	Maintains continuous operation without using battery power during brownout/undervoltage conditions to 173-300V AC (3-phase, 4-wire, wye). Below this point, output is maintained utilizing reserve battery power	
High Voltage Transfer to Battery Power (Setpoint)	Maintains continuous operation without using battery power during overvoltages to 276- 477V AC (3-phase, 4- wire, wye), reducing output within 1% of nominal. Above this point, output is maintained utilizing reserve battery power	
SPECIAL FEATURES		
Cold Start (Startup in Battery Mode During a Power Failure)	Cold-start operation supported	
High Availability UPS Features	Automatic inverter bypass; Hot swappable batteries	

LCD DISPLAY		
Input	Voltage, current	
Output	Voltage, frequency, current	
Batteries	Voltage	
Log (events memory)	Last events	
STANDARDS		
Safety	IEC 62040-1	
EMC	IEC 62040-2	
Design	IEC 62040-3	
Low magnetic field radiation	EMF as per ICNIRP	
WARRANTY		
Product Warranty Period	2-year comprehensive warranty and maintenance	

TECHNICAL SPECIFICATIONS FOR 1KVA RACK MOUNT UPS TO SUPPLY POWER FOR 4 HOURS

KenGen Specification	Compliance	Bidder's Offer (MUST FILL)
Topology	True on-line, double-conversion, VFI	
Operation	Continuous	
INPUT		
Voltage (nominal, Vac)	240, single-phase	
Voltage range (Vac)	160 ~ 276	
Current, max. (A)	7	
Frequency Compatibility	50 Hz	
Power factor (full load)	0.98	
OUTPUT		
Rated power (kVA / kW)	1 / 0.8	
Frequency range (%)	±1 (battery mode)	
Voltage (Vac)	220±1 %, single-phase	
Current (A)	5.4	
Frequency Compatibility	50 Hz	
Overload	105 % ~ 130 % transfer to bypass after 1 minute >130 % transfer to bypass after 1 sec, no output after 1 min.	
Waveform	Sinusoidal	
THD (%)	<2 for linear load	
Load CF (max)	3:1	
Power factor	0.8	

BATTERIES		
Type	Sealed, lead acid, rechargeable, maintenance-free	
Battery Volt-Amp-Hour capacity	4 hours	
GENERAL		
Ambient temperature	(°C) -10 to +40 (operating and storage)	
Relative humidity (%)	95 max. (non-condensing)	
Altitude (m)	1000 without derating (derating table below)	
Cooling system	Forced air (multi-fan with speed control)	
LCD DISPLAY		
Input	Voltage, current	
Output	Voltage, frequency, current	
Batteries	Voltage	
Log (events memory)	Last 200 events	
PHYSICAL		
Rack height	2U	
Width	19 inch	
STANDARDS		
Safety	IEC 62040-1	
EMC	IEC 62040-2	
Design	IEC 62040-3	
Low magnetic field radiation	EMF as per ICNIRP	
WARRANTY		
Product Warranty Period	2-year comprehensive warranty and maintenance	

TECHNICAL SPECIFICATIONS FOR PDU

ITEM/Specification	Minimum Specification	KenGen	Bidder's Offer (MUST FILL)
PDU			
Output			
Nominal Output Voltage	240V		
Maximum Total Current Draw	16 A		
Output Connections	(4) IEC 320 C19 (Battery Backup)		
	(20) IEC 320 C13 (Battery Backup)		
Input			
Nominal Input Voltage	240V		

Input frequency	50/60 Hz	
Input Connections	IEC-320 C20	
Cord Length	3.05 meters	
Number of Power Cords	1	
Load Capacity	3680 VA	
Maximum Input Current	16 A	
Physical	Rack mounted ,Vertical	
Environmental	Conform	
Conformance		
Approvals	CE, GOST, IRAM, VDE	
Standard warranty	2 years repair or replace	
ELECTRICAL MATERIALS		
3 Point Switch: Bypass, Off and UPS Supply switch		
3 Pole MCCB 100amperes		
Complete 6way DB		
Other Installation accessories	Please itemize	

OTHER GENERAL REQUIREMENTS FOR ALL THE EQUIPMENTS

ITEM/Specification	Minimum Specification	KenGen	Bidder's Offer (MUST FILL)
Sustainability:	Should be high efficient		
Serviceability	Front-access servicing Simplifies installation and UPS maintenance while minimizing space requirements.		
Availability			
Wide input voltage range:	Designed for harsh electrical environments to save battery life.		
Dual feed input:	Allows installation of two independent power sources with the option of hot stand-by configuration to provide redundancy for mission critical applications.		
Parallel-redundant capable:	Power the connected equipment with multiple uninterruptible power supplies to increase system redundancy		
Double conversion on-line topology	Guarantees a consistently high level of power quality. Any disturbances on the		

	distribution waveform are regenerated via the zero transfer time AC to DC then DC to AC conversion process. The battery is only used as a back-up source	
a) Installation and commissioning	Equipment shall be installed and commissioned at the user's facility by the Service Engineer followed by a five working day training at the user's facility for at least 6 staff after installation and commissioning at the supplier's cost. The stated scope of application for the equipment must be demonstrated during commissioning using installation standards and a real sample.	
b) SLA for Warranty Period (2 Years)	A Sample SLA -Service Level agreement should be attached with the bid offer; to be negotiated with client by winning bidder. The SLA terms will include, but not limited to, whole product, faulty parts, quarterly maintenance and user support in the event of equipment faults.	
c) Operation and service manuals	Hardware and operator's manual complete with methods shall be supplied and written in English.	
d) Warranty:	Two year warranty.	
e) Manufacturer's authorization	Must be provided	
f) Brochure	Must be provided.	
g) As Built	Must be submitted after installations & commissioning.	

TECHNICAL SPECIFICATIONS FOR TRUE RMS DIGITAL MULTIMETER

ITEM/Specification	Minimum Specification	KenGen	Bidder's Offer (MUST FILL)
Voltage DC			
Accuracy	$\pm(0.09\% + 2)$		
Max. resolution	0.1 mV		
Maximum	1000 V		
Voltage AC			
Accuracy	$\pm(1.0\% + 3)$		
Max. resolution	0.1 mV		
Maximum	1000 V		
Current DC			
Accuracy	$\pm(1.0\% + 3)$		
Max. resolution	0.01 mA		
Maximum	10 A		
Current AC			
Accuracy	$\pm(1.5\% + 3)$		
Max. resolution	0.01 mA		
Maximum	10 A		
Resistance			
Accuracy	$\pm(0.9\% + 1)$		
Max. resolution	0.1 Ω		
Maximum	50 M Ω		
Capacitance			
Accuracy	$\pm(1.2\% + 2)$		
Max. resolution	1 nF		
Maximum	10,000 μ F		
Frequency			
Accuracy	$\pm(0.1\% + 1)$		
Max. resolution	0.01 Hz		
Maximum	100 kHz		
Temperature			

Accuracy	±(1.0% + 10)	
Max. resolution	0.1°C	
Range	-40°C / 400°C	
Environmental Specifications		
Operating temperature	-10°C to +50°C	
Storage temperature	-30°C to +60°C	
Humidity (without condensation)	0% – 90% (0°C – 35°C) 0% – 70% (35°C – 50°C)	
Safety Specifications		
Overvoltage category	EN 61010–1 to 1000 V CAT III EN 61010–1 to 600 V CAT IV	
Agency approvals	UL, CSA, TÜV listed and VDE Pending	
Mechanical and General Specifications		
Size	43 x 90 x 185 mm	
Weight	420 g	
Warranty	Lifetime	
Battery life	Alkaline ~200 hours typical, without backlight	
Battery type	9V alkaline	

CABLE IQ QUALIFICATION TESTER - NETWORK CABLE TESTER SPECIFICATIONS

ITEM/Specification	Minimum KenGen Specification	Bidder's Offer (MUST FILL)
Cable types supported	UTP, STP, FTP, SSTP, RG6, RG59, audio and security	
Qualification auto tests	1000BASE-T, 100BASE-TX, 10BASE-T, VoIP, 1394b S100, TELCO, Wiremap only, Coax	
Supported tests	Wiremap, length, cable signal performance, digital toner, analog toner, Ethernet port detection and identification, analog telephone detection, blink port light, continuity, speaker test, cable fault finding, video signal detection.	

Wiremap	Can detect single wire faults and supports MultiMap mode with up to seven remote office identifiers. Draws proportional wire length to breaks. Detects split pairs.	
Find fault	Measures crosstalk and impedance and compares against appropriate limits based on qualification test selected. Detects location of large point sources as well as distributed sources in the cabling if they are sufficient to disqualify the application	
Results storage	Up to 250 qualification test results	
Power	Battery type: 4 AA (NEDA 15A, IEC LR6) alkaline batteries	
Battery life	20 hours of typical use, without backlight	
Other battery types supported	4AA photo lithium, NIHM, NICAD	
Dimensions and weight	7in x 3.5in x 1.75in (17.8cm x 8.9cm x 4.5cm) 1.2 lb (0.55 kg)	

Installation and commissioning

Training

A comprehensive training on the handling and maintenance of the UPS system shall be conducted by the contractor to client Support team of 4 (Four) to equip them with sufficient knowledge on how to maintain and carry out future modifications on the system. This shall take 3 days and shall be done before the commencement of the installation works at the vendors premises. The UPS should be easy to handle and maintain with training. Product guides, and any other training materials should be passed to the ICT personnel.

Equipment shall be installed and commissioned at the user's facility by the Service Engineer. The stated scope of application for the equipment must be demonstrated during commissioning using installation standards and a real sample.

SLA for Warranty Period (2 Years)

A Sample SLA-Service Level agreement should be attached with the bid offer. The SLA terms will include, but not limited to, whole product, faulty parts, quarterly maintenance and user support in the event of equipment faults.

Operation and service manuals

Hardware and operator's manual complete with methods shall be supplied and should be written in English.

As Built

As built drawings and operational instructions manuals shall be presented to the client with detailed information on the installation works and locations of the various equipment. This should include acceptance test and capacity test of 8 hours for the batteries. This documentation should include the results of successful capacity/load/discharge testing.

SECTION VI

SCHEDULE OF REQUIREMENTS

No.	DESCRIPTION	UNIT	QTY
1	40KVA/32KW UPS	Piece	1
2	20KVA/16KW UPS	Piece	1
3	1 KVA/0.8KW UPS	Piece	20
4	PDU	Piece	2
5	TRUE RMS DIGITAL MULTIMETER	Piece	5
6	CABLE IQ QUALIFICATION TESTER	Piece	1
7	TRAINING	3 days	4

SECTION VII

PRICE SCHEDULE FOR GOODS

No.	DESCRIPTION	UNIT	QTY	UNIT PRICE (KES)	TOTAL PRICE (KES)
1	40KVA/32KW UPS	Piece	1		
2	20KVA/16KW UPS	Piece	1		
3	1 KVA/0.8KW UPS	Piece	20		
4	PDU	Piece	2		
5	TRUE RMS DIGITAL MULTIMETER	Piece	5		
6	CABLE IQ QUALIFICATION TESTER	Piece	1		
7	TRAINING	3 days	4		
8	Other materials required carry out implementation to meet scope (List and indicate costs)				
9	Cost of installation,testing and Commissioning	Lot	1		
Total Cost					
Discount (%) if any					
Other Charges e.g. transport, handling, etc					
Add 16% VAT					
Less Withholding Income Tax on the Service Component. Please refer to the Clause 3.21.3 on Local Taxation.					
Total Cost Delivery Duty Paid (DDP) to Olkaria					
Delivery period (in months)					

Tenderer's name (Company) _____

Signature & Rubber-stamp _____ Date _____

NOTES

- Award shall be based on the total lowest evaluated bid for all items.
- Documentary evidence to prove that the equipment offered comply with the Technical Specifications **must** be provided.
- The tenderer must quote as per the Technical Specifications in the Tender Document.
- Bids that do not conform to the Technical Specifications shall be disqualified.

Note: In accordance with **Clause 82** of the **Public Procurement and Asset Disposal Act 2015**. “The tender sum as submitted and read out during the tender opening shall be absolute and final and shall not be the subject of correction, adjustment or amendment in any way by any person or entity.

BRAND/MAKE AND COUNTRY OF ORIGIN

No.	DESCRIPTION	UNIT	QTY	Brand/Make (Indicate)	Country of Origin (Indicate)
1	40KVA/32KW UPS	Piece	1		
2	20KVA/16KW UPS	Piece	1		
3	1 KVA/0.8KW UPS	Piece	20		
4	PDU	Piece	2		
5	TRUE RMS DIGITAL MULTIMETER	Piece	5		
6	CABLE IQ QUALIFICATION TESTER	Piece	1		

**SECTION VIII
STANDARD FORMS**

8.1 FORM OF TENDER

Date _____
Tender No. _____

To: _____

[name and address of procuring entity]

Gentlemen and/or Ladies:

1. Having examined the tender documents including Addenda Nos. *[insert numbers]*.the receipt of which is hereby duly acknowledged, we, the undersigned, offer to supply deliver, install and commission (..... *(insert equipment description)* in conformity with the said tender documents for the sum of *(total tender amount in words and figures)* or such other sums as may be ascertained in accordance with the Schedule of Prices attached herewith and made part of this Tender.

2. We undertake, if our Tender is accepted, to deliver install and commission the equipment in accordance with the delivery schedule specified in the Schedule of Requirements.

3. If our Tender is accepted, we will obtain the guarantee of a bank in a sum of equivalent to _____ percent of the Contract Price for the due performance of the Contract , in the form prescribed by*(Procuring entity)*.

4. We agree to abide by this Tender for a period of *[number]* days from the date fixed for tender opening of the Instructions to tenderers, and it shall remain binding upon us and may be accepted at any time before the expiration of that period.

5. This Tender, together with your written acceptance thereof and your notification of award, shall constitute a Contract, between us, subject to signing of the Contract by the parties.

6. We understand that you are not bound to accept the lowest or any tender you may receive.

Dated this _____ day of _____ 20 _____

[signature]

[in the capacity of]

Duly authorized to sign tender for an on behalf of _____

8.2 MANDATORY CONFIDENTIAL BUSINESS QUESTIONNAIRE

(Must be filled by all applicants or Tenderers' who choose to participate in this tender)

Name of Applicant(s).....

You are requested to give the particulars in Part 1 and either Part 2 (a), 2 (b) or 2 (c), whichever applies to your type of business. Part 2 (d) to part 2 (i / j) must be filled. You are advised that giving wrong or false information on this Form will lead to automatic disqualification/termination of your business proposal at your cost.

Part 1 – General

Business Name:.....Certificate of Incorporation /
Registration No. Location of business premises:
CountryPhysical address
TownBuilding.....
Floor.....Plot No.
Street / RoadPostal Address
Postal / Country Code.....Telephone No's.....
Fax No's.E-mail address
Website
Contact Person (Full Names) Direct / Mobile No's.....
Title Power of Attorney (Yes / No)
If **yes**, attach written document.
Nature of Business (Indicate whether manufacturer, distributor, etc)

(Applicable to Local suppliers only)

Local Authority Trading License No. Expiry Date
Value Added Tax
No.....
Value of the largest single assignment you have undertaken to date (USD/KShs)
.....
Was this successfully undertaken? **Yes / No**(If **Yes**, attach reference)
Name (s) of your banker (s)
.....
Branches Tel. No's.

Part 2 (a) – Sole Proprietor (if applicable)

Full names
Nationality..... Country of Origin.....
.....
Company Profile (Attach brochures or annual reports in case of public company)

Part 2 (b) – Partnerships (if applicable)

Give details of partners as follows:

Full Names Nationality Citizenship Details Shares

1.
2.
Company Profile (Attach brochures)

Part 2 (c) – Registered Company (if applicable - as per the CR12 form)

Private or public
Company Profile (Attach brochures or annual reports in case of public companies)
State the nominal and issued capital of the Company
Nominal KShs
Issued KShs
List of top ten (10) shareholders and distribution of shareholding in the company. Give details of all directors as follows:-

Full Names Nationality Citizenship Details Shares

1.....
2.....

Part 2 (d) – Debarment

I/We declare that I/We have not been debarred from any procurement process and shall not engage in any fraudulent, corrupt, coercive and obstructive acts with regard to this or any other tender by the KENGEN and any other public or private institutions.

Full Names
.....
Signature
.....

Dated this day of 2017.
In the capacity of

Duly authorized to sign Tender for and on behalf of

Part 2 (e) – Bankruptcy / Insolvency / receivership.

I/We declare that I/We have not been declared bankrupt or insolvent by the competent Authorities in Kenya and neither are we under receivership:

Full Names
Signature
.....

Dated this day of 2017.
In the capacity of

Duly authorized to sign Tender for and on behalf of

Part 2 (f) – Criminal Offence

I/We, (Name (s) of Director (s)):-

- a)
- b)

Have not been convicted of any criminal offence relating to professional conduct or the making of false statements or misrepresentations as to its qualifications to enter into a procurement contract within a period of three (3) years preceding the commencement of procurement proceedings.

Signed
.....
For and on behalf of M/s

In the capacity of

Dated this day of 2017.

Suppliers’ / Company’s Official Rubber Stamp
.....

Part 2 (g) – Conflict of Interest

I/We, the undersigned state that I / We have no conflict of interest in relation to this procurement:

- a)
- b)

For and on behalf of M/s

In the capacity of

Dated this day of 2017

Suppliers’ / Company’s Official Rubber Stamp
.....

Part 2 (h) – Interest in the Firm:

Is there any person/persons in KENGEN or any other public institution who has interest in the Firm? Yes/No

..... (Delete as necessary) Institution

(Title) (Signature) (Date)

Part 2 (i or j) – Bank account details:

AGPO firms must provide evidence from their bank that the account to which KenGen shall make payment has a youth or a woman or a PWD listed in the **CR12 form/partnership deed/sole proprietor certificate** as a MANDATORY signatory of that account,- **Sec.157 (11) of PPADA:**

Account No:.....*Name of the person(s) in the CR12 form OR in the partnership deed OR in the partnership certificate*.....
OR
in the sole proprietor certificate...../.....

ID No(s):...../.....*Signature and stamp of the authorized Banker Representative*.....
Date.....

Part 2(j or k) – Declaration

I / We, the undersigned state and declare that the above information is correct and that I / We give KENGEN authority to seek any other references concerning my / our company from whatever sources deemed relevant, e.g. Office of the Registrar of Companies, Bankers, etc.

Full names
.....
Signature.....
For _____ and _____ on _____ behalf _____ of _____ M/s _____
.....
In the capacity of
.....
Dated this _____ day of _____ 2017.
Suppliers' / Company's Official Rubber Stamp
.....

Note: In accordance with **Clause 82** of the **Public Procurement and Asset Disposal Act 2015.**

“The tender sum as submitted and read out during the tender opening shall be absolute and final and shall not be the subject of correction, adjustment or amendment in any way by any person or entity.

8.3 TENDER SECURITY FORM

(To be on the Banks Letterhead)

WHEREAS [name of the tenderer]
(hereinafter called “the tenderer”) has submitted its tender dated
..... [date of submission of tender] for
.....[name and/or description of the equipment]
(hereinafter called “the Tender”)

KNOW ALL PEOPLE by these presents that **WE** of
..... having our registered office at
..... (hereinafter called “the Bank”), are bound unto
the **Kenya Electricity Generating Company Limited** (hereinafter called “the
Procuring entity”) in the sum of for which
payment well and truly to be made to you, the Bank binds itself, its
successors, and assigns by these presents.

Sealed with the Common Seal of the said Bank this _____ day of _____
20

THE CONDITIONS of this obligation are:-

1. If the tenderer withdraws its Tender during the period of tender validity specified by the tenderer on the Tender Form; or
2. If the tenderer, having been notified of the acceptance of its Tender by the Procuring entity during the period of tender validity:
 - (a) fails or refuses to execute the Contract Form, if required; or
 - (b) fails or refuses to furnish the performance security in accordance with the Instructions to tenderers;

We undertake to pay the Procuring entity up to the above amount upon receipt of its first written demand, without the Procuring entity having to substantiate its demand, provided that in its demand the Procuring entity will note that the amount claimed by it is due to it, owing to the occurrence of one or both of the two conditions, specifying the occurred condition or conditions.

This tender guarantee will remain in force up to and including thirty (30) days after the period of tender validity, and any demand in respect thereof should reach the Bank not later than the above date.

[Signature of the bank] _____
(Amend accordingly if provided by Insurance Company)

8.4 CONTRACT FORM

THIS AGREEMENT made the _____ day of _____ 20 ____ between
..... [name of the Employer] of [country of the Employer] (hereinafter
called “the Employer) of the one part and [name of the Supplier] of
..... [city and country of the Supplier] (hereinafter called “the Supplier”) of the
other part;

WHEREAS the Employer invited tenders for] and has accepted a tender by
the tenderer for the supply of in the sum of
[contract price in words and figures] (hereinafter called “the Contract Price).

NOW THIS AGREEMENT WITNESSETH AS FOLLOWS:

1. In this Agreement words and expressions shall have the same meanings as are respectively assigned to them in the Conditions of Contract referred to:
2. The following documents shall be deemed to form and be read and construed as part of this Agreement viz:
 - (a) the Tender Form and the Price Schedule submitted by the tenderer
 - (b) the Schedule of Requirements
 - (c) the Technical Specifications
 - (d) the General Conditions of Contract
 - (e) the Special Conditions of contract; and
 - (f) the Procuring entity’s Notification of Award and Tenderer’s Acceptance
 - (g) Applicable addenda and clarifications
3. In consideration of the payments to be made by the Procuring entity to the tenderer as hereinafter mentioned, the tenderer hereby covenants with the Procuring entity to provide the goods and to remedy defects therein in conformity in all respects with the provisions of the Contract
4. The Procuring entity hereby covenants to pay the tenderer in consideration of the provisions of the goods and the remedying of defects therein, the Contract Price or such other sum as may become payable under the provisions of the Contract at the times and in the manner prescribed by the contract.

IN WITNESS whereof the parties hereto have caused this Agreement to be executed in accordance with their respective laws the day and year first above written.

Signed by _____ the _____ (for the Procuring entity

Signed by _____ the _____ (for the tenderer in the presence of _____

(Amend accordingly if provided by Insurance Company)

8.5 PERFORMANCE SECURITY FORM
(To be on the Banks Letterhead)

To
[name of Procuring entity]

WHEREAS [name of tenderer]
(hereinafter called “the tenderer”) has undertaken , in pursuance of Contract
No. _____ [reference number of the contract] for dated _____
_____ 20 _____ to _____ supply
..... [description of goods]
(hereinafter called “the Contract”).

AND WHEREAS it has been stipulated by you in the said Contract that the tenderer shall furnish you with a bank guarantee by a reputable bank for the sum specified therein as security for compliance with the Tenderer’s performance obligations in accordance with the Contract.

AND WHEREAS we have agreed to give the tenderer a guarantee:

NOW THEREFORE WE hereby affirm that we are Guarantors and responsible to you, on behalf of the tenderer, up to a total of [amount of the guarantee in words and figure] and we undertake to pay you, upon your first written demand declaring the tenderer to be in default under the Contract and without cavil or argument, any sum or sums within the limits of [amount of guarantee] as aforesaid, without you needing to prove or to show grounds or reasons for your demand or the sum specified therein.

This guarantee is valid until the _____ day of _____ 20 ____

Signed and seal of the Guarantors

[name of bank or financial institution]

[address]

[date]

8.6 MANUFACTURER'S AUTHORIZATION FORM

To *[name of the Procuring entity]*

WHEREAS*[name of the manufacturer]* who are established and reputable manufacturers of *[name and/or description of the goods]* having factories at *[address of factory]* do hereby authorize *[name and address of Agent]* to submit a tender, and subsequently negotiate and sign the Contract with you against tender No. *[reference of the Tender]* for the above goods manufactured by us.

We hereby extend our full guarantee and warranty as per the General Conditions of Contract for the goods offered for supply by the above firm against this Invitation for Tenders.

[signature for and on behalf of manufacturer]

Note: This letter of authority should be on the letterhead of the Manufacturer and should be signed by a person authorized.