

19th March 2018
ADDENDUM 1.



KGN-SBP-02-2018

TENDER FOR DESIGN, SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF SMART SOLAR GRID-TIE SYSTEM FOR KIPEVU OFFICE BLOCK, INTEGRATED SOLAR STREET LIGHTING AND LED RETROFIT MAST LIGHTING AT KIPEVU POWER STATIONS.

CLAUSE	CLARIFICATION						
INSTRUCTIONS TO TENDERERS REFERENCE Clause 2.5.1 pg 14	The Procuring entity will respond in writing to any request for clarification of the tender documents, which it receives not later than seven (7) days prior to the deadline for the submission of tenders.						
SCHEDULE II: GRID - TIE SYSTEM FOR KIPEVU POWER STATION OFFICE BLOCK							
	<p>Based on the requirements reviewed for this schedule, KenGen would like to issue the following clarification with regards to scope of work: Based on the load requirement for the kipevu power station office block, the grid tie system sizing shall be of 40kW grid-Tie. Please take note of the following additional information:</p> <table border="1" data-bbox="535 934 1412 1108"> <thead> <tr> <th data-bbox="540 940 711 970">ITEM</th> <th data-bbox="711 940 1408 970">SPECIFICATION</th> </tr> </thead> <tbody> <tr> <td data-bbox="540 970 711 1041">System Load</td> <td data-bbox="711 970 1408 1041">40 kW</td> </tr> <tr> <td data-bbox="540 1041 711 1108">Roofing Area</td> <td data-bbox="711 1041 1408 1108">406 M²</td> </tr> </tbody> </table> <p>Roof Orientation</p> <div data-bbox="787 1155 1323 1869"> </div>	ITEM	SPECIFICATION	System Load	40 kW	Roofing Area	406 M ²
ITEM	SPECIFICATION						
System Load	40 kW						
Roofing Area	406 M ²						

	All other requirements of schedule II remain the same
--	---

ALL OTHER TERMS AND CONDITION REMAIN THE SAME

ACKNOWLEDGEMENT OF ADDENDUM NO.1

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in the Addendum have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date