



KENYA ELECTRICITY GENERATING COMPANY LIMITED

DATE: 4/05/2018.

KGN-GDD-051-2018: TENDER FOR SUPPLY OF ASSORTED INDUCTION MOTORS AND ACCESSORIES FOR OLKARIA POWER STATIONS

ADDENDUM NO.1

In accordance with the tender for the: “Supply of Assorted Induction Motors and Accessories for Olkaria Power Stations. KenGen hereby issues **Addendum No.1**

Induction Motor Specifications	
1	<p>1. <u>Schedule A</u></p> <p>Under Technical specifications Schedule A for the Auxiliary Cooling water pump motor, the rating is stated as 160KW. What is required is 132KW Auxiliary water Cooling pump Induction motor.</p> <p>2. <u>Schedule B</u></p> <p>Under Schedule B, the Existing details for the Cooling tower fan motor is stated as 57KW. What is required is a 37KW Cooling tower fan motor</p>

ACKNOWLEDGEMENT OF ADDENDUM NO.1

We, the undersigned hereby certify that the Addendum is an integral part of the document and the alterations set out in the Addendum have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....