



KENYA ELECTRICITY GENERATING COMPANY PLC.

KGN-HYD-048-2018.

**TENDER FOR REHABILITATION (PAINTING AND CEILING) WORKS FOR MASINGA POWER STATION.**

19<sup>th</sup> December, 2018.

**ADDENDUM NO 1.**

In Accordance with the Tender for “Rehabilitation (Painting and Ceiling) Works for Masinga Power Station”. KenGen hereby issues **Addendum No.1**

**PAINTING AND CEILING WORKS.**

ITEM	DESCRIPTION	UNIT	QTY	RATE (Kshs.)	AMOUNT (Kshs.)
A	Prepare surface by <b>SCRUBBING OFF THE EXISTING OIL BASED</b> paints and apply <b>TWO</b> layers undercoat and <b>THREE</b> finishing coats of first Vinyl silk paints Dura coat or equivalent to Walls, beams and column surfaces internally	m <sup>2</sup>	1570		
B	Prepare surface by <b>SCRUBBING OFF THE EXISTING WATER BASED</b> paints and apply <b>TWO</b> layers undercoat and <b>THREE</b> finishing coats of Plastic emulsion paints Dura coat or equivalent to soffits of ceiling	m <sup>2</sup>	1300		
C	Prepare surface by <b>SCRUBBING OFF THE EXISTING OIL BASED</b> paints and apply <b>TWO</b> layers undercoat and <b>THREE</b> finishing coats	m	350		

ITEM	DESCRIPTION	UNIT	QTY	RATE (Kshs.)	AMOUNT (Kshs.)
	Gloss paint to guard rails				
D	Supply and Fit 2×2, 3 lamp LED fittings, 18 watts.	Pcs	50		
E	Supply and Fit emergency light Bulkhead LED lamps, 3-hour operations, 5 watts	Pcs	10		

**ACKNOWLEDGEMENT OF ADDENDUM NO 1.**

We, the undersigned hereby certify that the Addendum is an integral part of the document and has been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....