



**TENDER NO. KGN-KIP-013-2018**

**TENDER FOR SUPPLY, INSTALLATION AND COMMISSIONING OF 30KVA UPS AT KIPEVU 1 POWER STATION.**

30<sup>th</sup> November 2018

**ADDENDUM NO.4**

In accordance with the TENDER FOR SUPPLY, INSTALLATION AND COMMISSIONING OF 30KVA UPS AT KIPEVU 1 POWER STATION KenGen hereby issues addendum No. 4.

<b>NO.</b>	<b>Bidders clarification</b>	<b>KenGen Response</b>
1.	At what load capacity will the battery test be done without mains to ascertain the battery backup period of 6 hours?	The loading is at 60KW
2.	Indicate the type, the rating and the number of batteries to achieve the backup time.	The batteries although it was not an issue we are going with either Nickel Cadmium or Lithium ion maintenance free batteries. The batteries material safety data sheet (msds) must be provided during the delivery of the items
3.	What is the number of contract days?	Please note that the contract shall be 120 days from the date of signing
4	What is the delivery Period?	Delivery period shall remain 30 days

**ALL OTHER TERMS AND CONDITIONS IN THE TENDER DOCUMENT REMAINS THE SAME**

**ACKNOWLEDGEMENT OF ADDENDUM NO.4**

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in the Addendum have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....