



KENYA ELECTRICITY GENERATING COMPANY LIMITED

**TENDER FOR SUPPLY, INSTALLATION, CONSTRUCTION AND COMMISSIONING
OF KENGEN DETERGENT MANUFACTURING PLANT – (OPEN NATIONAL –
ENGINEERING FIRMS) KGN-GDD-033-2018**

5th April 2018

ADDENDUM No.2

1	<p>Level Transmitters; Under clause 7.7 Instrumentation and control (3 Nos)</p> <p>Each of the tanks (Acid, sulphonic acid and reaction tank) shall be fitted with vertically mounted (on top) 240 VAC ultrasonic transmitters with inbuilt display and analog output (4-20 mA). The accuracy shall be 0.2%-0.5%. The transmitters shall be able to work in sulphonic acid environment (corrosion resistant) and exproof for class I Div I and Div II for groups B, C and D. The transmitters shall be integrated with the PLC for online monitoring as well as through local in built display.</p> <p>This item shall be an added line item in BOQ1 (Construction of detergent plant works) as item 4.18 with quantity 3 pieces.</p>
---	--

ACKNOWLEDGEMENT OF ADDENDUM No.2

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....