



KENYA ELECTRICITY GENERATING COMPANY LIMITED

TENDER NO. KGN-GDD-062-2018

DATE: 6/06/2018

TENDER FOR SUPPLY OF MATERIALS FOR CONNECTION OF MAKE UP WELL TO OLKARIA II  
STEAMFIELD

CLARIFICATION NO.1:

In accordance with the tender mentioned above, KenGen hereby issues Clarification No. 1:

No	Bidders Question	KenGen' Response
1.	Please provide Length of the bolts?	Bidders are advised to refer to the <b>revised table below for Schedule C – Specification of Stud Bolt and Nuts.</b>
2.	Do you need black painting or marking outside the surface for the pipes and fittings?	The pipes and fittings should be factory painted black on the outside and have markings indicating the materials specifications, nominal size, schedule etc
3.	What is their function?	Construction of steam lines
4.	Please provide drawings for the valves? Because we are not sure about the item 5&6 of STEAM VALVES. As you mentioned, should the position indicator be on the gear or pneumatic?	The drawings are not provided but the bidders are required to submit the detailed drawings of the valves they intend to supply as specified in the tender. These are manual gate valves that will be hand operated and not pneumatically operated.

**SCHEDULE C**  
**SPECIFICATIONS**  
**STUD BOLT AND NUTS**

		<b>STUD BOLTS AND NUTS</b>				
<b>ITEM</b>	<b>SIZE(DN) OF BOLT (INCH)</b>	<b>LENGTH OF BOLT (MM)</b>	<b>DESCRIPTION</b>	<b>QTY</b>	<b>MATERIAL SPECIFICATION</b>	<b>DIMENSION SPECIFICATION</b>
1.	1 1/4 "	220	Stud bolts and Heavy hex nuts <i>(The stud bolts are threaded full length)</i>	64	Bolts - ASTM A193 Gr B7 Nuts - ASTM A194 Gr 2H	ASME B18.2.1 ASME B18.2.2
2.	1 "	160	Stud bolts and Heavy hex nuts <i>(The stud bolts are threaded full length)</i>	48	Bolts - ASTM A193 Gr B7 Nuts - ASTM A194 Gr 2H	ASME B18.2.1 ASME B18.2.2
3.	7/8"	145	Stud bolts and Heavy hex nuts <i>(The stud bolts are threaded full length)</i>	32	Bolts - ASTM A193 Gr B7 Nuts - ASTM A194 Gr 2H	ASME B18.2.1 ASME B18.2.2
4.	5/8 "	110	Stud bolts and Heavy hex nuts <i>(The stud bolts are threaded full length)</i>	192	Bolts - ASTM A193 Gr B7 Nuts - ASTM A194 Gr 2H	ASME B18.2.1 ASME B18.2.2
5.	3/4 "	125	Stud bolts and Heavy hex nuts <i>(The stud bolts are threaded full length)</i>	108	Bolts - ASTM A193 Gr B7 Nuts - ASTM A194 Gr 2H	ASME B18.2.1 ASME B18.2.2

**ACKNOWLEDGEMENT OF CLARIFICATION NO. 1**

We, the undersigned hereby certify that the Clarification is an integral part of the document and has been incorporated in the tender document.

Signed .....

Tenderer: .....

Date: .....