



KENYA ELECTRICITY GENERATING COMPANY LIMITED

KENGEN TENDER: KGN-GDD-038-2018:

TENDER FOR SUPPLY OF INSTRUMENT SPARES FOR OLKARIA POWER PLANTS.

CLARIFICATION NO. 1:

In accordance with the tender for supply of instrument spares for Olkaria Power Plants, KenGen hereby issues Clarification No. 1.

Date: 16th March, 2018

	Remarks/Clarifications Required	Responses
1	Under Schedule 1: OLKARIA I item No. 3, what is the Serial No. of the existing Meter for Shimadzu	Kindly note the corrections given below for the said speed meter: Scale Range: 0-4000rpm Input: 0-5mA FS: 5mA 0.25VDC Diameter: 105mm Connection (from): MX- 102 Type:ML-110 Manufacture: Melco
2	Under Schedule 3: OLKARIA IAU & IV item No. 7 Model code has S2 in the code for factory Assembly of diaphragm seals. But no model code for the seals has been supplied. Please confirm these codes to enable us offer the appropriate item	Given below is the details for the diaphragm: Transmitter Diaphragm: DP0004-1122-S6 316L/3SE023-G10 1"150#1500#ANSI C14L187914 316L/12A0263 Transmitter Flange: DP0001.1015.S61150ASTMA182GR.316/316 LMM80
3	Under Schedule 3: OLKARIA IAU & IV item No. 9 kindly provide serial number (7 digit) and Yamari Drawing number starting with N or P / e.g.P-000000 OR Please send us reference drawing or advice the Yamari model. (E.g. TMPB-KD80 II /316L-400/U-KN-15/304-NPT1/2 / 304)	Given below is Additional information including the serial number of the existing item. The rest refer to the tender document. L400 DIA8.0D MTL316L S/NO:2764098 CLASS STD

1. L Length & U Length 2. Terminal Head type (Our Standard is KN) 3. O.D of Protection tube 4. Thread size	
---	--

ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the clarification is an integral part of the document and has been incorporated in the tender proposal.

Signed

Tenderer

Date.....