



KENYA ELECTRICITY GENERATING COMPANY PLC.

KGN-HYD-040-2018.

TENDER FOR SUPPLY STAINLESS STEEL FLANGES FOR KAMBURU POWER STATION.

28th November, 2018.

CLARIFICATION NO.1.

In Accordance with the tender for “Supply Stainless Steel Flanges for Kamburu Power Station”. KenGen hereby issues **Clarification no.1.**

NO	BIDDERS REQUEST	KENGEN’S RESPONSE
1	Kindly clarify expressly that the size required is M16 X 60mm or its M16 X 90mm. The Addendum attached on Item No. 3 states both specifications.	The size of the stainless steel bolts needed is size M16 X 60mm; Thread to be of metric pitch.

ACKNOWLEDGEMENT OF CLARIFICATION NO 1.

We, the undersigned hereby certify that the Clarification is an integral part of the document and has been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....