



TENDER NO. KGN-HYD-26-2018:

**TENDER FOR SUPPLY OF ASSORTED ELECTRICAL BUILDING ITEMS FOR
EASTERN HYDRO POWER STATIONS.**

In accordance with the tender for “supply of assorted electrical building items for eastern hydro power stations, KenGen hereby issues

Clarification No.1

NO.	CLARIFICATION REQUESTED	RESPONSE TO THE BIDDER
1.	Item No 32	30 A
2.	Item No 33 Confirm if they are also known as strip connectors	10 A Confirmed. They are connectors also known as strip connectors
3.	Item No. 29. Show full details	Cable PVC 2.5 mm (Single Core Black)
4.	Item No. 38 What is the type of reinforcement?	Reinforced Rubber Hose pipe $\frac{3}{4}$ inch (Reinforcement is Fibre)

ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the Clarification have been incorporated in the tender proposal.

Signed.....

Tenderer.....

Date.....