



KENYA ELECTRICITY GENERATING COMPANY LIMITED

DATE: 8/02/2018

TENDER NO. KGN-TURK-02-2018: TENDER FOR MANUFACTURE AND SUPPLY OF TURBINE SHAFT SEAL AND MAIN INLET VALVE PARTS FOR TURKWEL POWER STATION

I. CLARIFICATION 2

In accordance with the tender mentioned above, KenGen hereby issue Clarification No. 1

NO.	ISSUE/ QUERY	PROCURING ENTITY'S RESPONSE	REQUIREMENT FOR ADDENDUM
1	Pg 39 & Pg 40 - Price Schedule quantities mentioned is 1 LOT for SHAFT SEAL PARTS & MIV SEAL RINGS, whereas on Pg 33 says "Machine and supply four carbon seal segment carriers and four seal runner plates as per sample." & Pg 35 & 36 says" Supply one stationary ring machined from France AFNOR Z20C13stainless steel & Supply one mobile ring machined from France AFNOR Z20C13 stainless steel" - WE REQUEST YOU TO KINDLY CLARIFY THE EXACT QUANTITY REQUIRED.	<p>With reference to the samples that were viewed on 01/02/2018 at KenGen central workshop.</p> <ul style="list-style-type: none"> • The MIV parts comprise a mobile ring and a stationary ring. We require one of each. • The shaft seal runner plate comprises four segments. We require the four segments. • The carbon seal carrier plate comprises four segment onto which carbon material is attached. We require the four segments. 	This clarification does not require an Addendum to the Tender Document.
2	Drawings – OEM drawings for the parts in the scope of supply.	Drawings detailing all the dimensions and geometric features are not available. That is why viewing of the samples was mandatory. However please receive some working drawing	This clarification does not require an Addendum to the Tender Document.

		showing some few details. See sketch 1, sketch 2, and MIV seal cross section.	Attached pdf drawings to be uploaded/ appended to the tender document
3	KINDLY PROVIDE THE DIMENSIONS OF THE CARBON RING, AS THE RING ON THE SAMPLE IS WORN OUT.	When finally done the height of the carbon material when measured from the surface of the carrier plate shall be 10mm. See sketch 1.	This clarification does not require an Addendum to the Tender Document.

ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the clarification is an integral part of the document and has been incorporated in the tender document.

Signed

Tenderer

Date