



KENYA ELECTRICITY GENERATING COMPANY LIMITED

KGN-GDD-020-2017

TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF HIGH PERFORMANCE 180AMPERE HOUR BATTERIES FOR OLKARIA II POWER STATION

4th April 2017

CLARIFICATION No.1

In accordance with the TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF HIGH PERFORMANCE 180AMPERE HOUR BATTERIES FOR OLKARIA II POWER STATION, KenGen hereby issues **Clarification No. 1**

No.	ITEM DESCRIPTION	Clarification
1.	Dimensions of the batteries currently in use	306(L)X168(W)X227(H) dimensions in mm.
2.	Drawing of the existing rack	Kindly see attached photograph.
3	How many tiers and lines of original battery rack design	2 tier. 2 rows per tier. See attached photo
4.	Inner dimensions per block in the battery rack	Around 30.8cm
5.	Maximum discharge current of the battery rack. Battery capacity	182A at nominal current 180AH/10HR
6.	UPS backup time request	10hrs



ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in clarification has been incorporated in the tender proposal.

Signed

Tenderer