



KENYA ELECTRICITY GENERATING COMPANY LIMITED

KG-N-GDD-04-2018

**TENDER FOR SUPPLY OF ELECTRICAL SPARES FOR DRILLING RIGS FOR
GEOHERMAL DEVELOPMENT DIVISION**

9th February, 2018.

CLARIFICATION NO. 2:

In accordance with the tender for supply of electrical spares for drilling rigs, KenGen hereby issues Clarification No. 3.

ITEM	Bidders Request	KenGen Response
1	<p>Could you please clarify whether armoured cables can be used in place of flexible cables for the following items listed under schedule B</p> <p>No. 10 HO7RN-F HEAVY DUTY FLEXIBLE POWER CABLE, FOUR CORE BY 25mm2</p>	<p>Armoured cables cannot be used in this application.</p>
2	<p>Could you please clarify the current values and the phase needed for the below items listed under Schedule C: Electrical Panel Accessories.</p> <p>Schneider Electric Masterpact Air Circuit Breaker.Model: MT20 H1</p> <p>Schneider Electric Masterpact Air Circuit Breaker. Model: MT08 N1</p>	<p>2000 Amps, 690 V, Poles: 3</p> <p>800 Amps, 690 V, Poles: 3</p> <p>2000 Amps, 690 V, Poles: 3</p> <p>1250 Amps, 690 V, Poles: 3</p>
3	<p>Could you please clarify whether the Split System Condensing Unit Model No. TRANE TTA075ADFN and the Split System Air Handler Model No. TRANE TWE075ADFN listed under Schedule E No.1 and No.2</p>	<p>They cannot be of another model as they are meant to fit an existing footprint.</p>

ACKNOWLEDGEMENT OF CLARIFICATION NO.2

We, the undersigned hereby certify that the clarification is an integral part of the document and has been incorporated in the tender proposal.

Signed

Tenderer

Date.....