



KENYA ELECTRICITY GENERATING COMPANY LIMITED

KGN-FUEL-06-2016

Open National Tender for Supply and Delivery Of  
Automotive Gas Oil to Drilling Rigs at Olkaria  
Geothermal Development

11<sup>th</sup> January 2016

CLARIFICATION NO. 1

In accordance with the tender mentioned above, KenGen hereby issue Clarification No. 1:

Clarification Sought	Response
The tender document mentions use of flow meters to determine the quantity delivered but there are no flowmeters installed.	The quantity delivered will be measured using the truck ullage mark and dipsticks. Suppliers shall ensure that trucks have valid calibration charts at all times.
Do KenGen rig tanks have valid calibration tanks for measuring deliveries?	The quantity delivered will be measured using the truck ullage mark and dipsticks. Suppliers shall ensure that trucks have valid calibration charts at all times.
Can KenGen make their site more convenient for access by large trucks?	The specific logistics and terrain of each site are unique. KenGen shall however ensure that the supplier is informed of the terrain and access when placing delivery orders and advice on the best truck size. Suppliers are also advised to ensure they familiarize themselves with all sites when the rigs are shifted.

ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned hereby certify that the clarification is an integral part of the document and has been incorporated in the tender document.

Signed .....

Tenderer: .....

Date .....