



KENYA ELECTRICITY GENERATING COMPANY LIMITED

**KGN -GDD-05-2019
TENDER FOR SUPPLY OF BRINE EVACUATION PUMP AND ACCESSORIES
FOR GEOTHERMAL STEAMFIELD MANAGEMENT
(Reserved for Enterprises owned by Youth)**

7th February 2019

CLARIFICATION NO.1- PH

In accordance with the **TENDER FOR SUPPLY OF BRINE EVACUATION PUMP AND ACCESSORIES FOR GEOTHERMAL STEAMFIELD MANAGEMENT**, KenGen hereby issues Clarification No.1

NO	BIDDER'S REQUEST	KenGen RESPONSE
I)	We need to confirm the final clarity on the PH of the brine is it acidic or alkaline? Please confirm	Brine PH is Alkaline

ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned hereby certify that the clarification is an integral part of the document and the alterations set out in the addendum has been incorporated in the tender proposal.

Signed _____

Tenderer _____