

KENYA ELECTRICITY GENERATING COMPANY LTD



TENDER No. GN-HYD-022-2017 TENDER FOR MANUFACTURE SUPPLY TESTING AND COMMISSIONING OF AN EMERGENCY DIESEL GENERATOR FOR KAMBURU HYDRO POWER STATION

CLARIFICATIONS 3

04/10/2017

The clauses listed have been amended to read as written in the amended article column

NO.	QUERY	CLARIFICATION
1.	Can you please advise the PLC type and part number used at the main building and the equipment – if any - that the contractor must supply i.e. I/O modules, Power Supplies cabinets , etc.	<i>The scope of the contractor only covers provision of Voltage-free contacts for the EDG signals as stipulated in the tender technical specifications clause 6.3. These EDG signals shall be wired up to the Main 415Vac Board Terminal Blocks. The interfacing of the signals to the existing equipment shall be done in conjunction with the client engineers.</i>

All other terms and conditions remain as per the tender document

ACKNOWLEDGEMENT OF CLARIFICATION 2

We, the undersigned hereby certify that the addendum is an integral part of the document and has been incorporated in the tender proposal.

Signed

Date

Tenderer