

KENYA ELECTRICITY GENERATING COMPANY

16th March 2017

**TENDER FOR SUPPLY OF MEDIUM AND HIGH VOLTAGE CIRCUIT
BREAKER TESTER FOR CENTRAL WORKSHOP: KGN-CW-01-2017**

KenGen wishes to issue the following additional information on the tender in question through Clarification 1:

No	Issue of clarification	KenGen clarification
1	Circuit Breaker Tester can meet all your technical demands except the contact resistance test function. can we offer a separate unit which can test the contact resistance	The Circuit breaker tester shall meet all our technical demands inclusive of the contact resistance test all integrated in a SINGLE BOX solution as clearly stated in the tender document
2	Kindly clarify on whether it is the tenderer's responsibility to provide accommodation and travel to the KenGen Engineers during the Factory acceptance test and training	The tenderer/supplier shall meet the cost of training in totality .This includes, cost of training, cost of training materials, travel and accommodation during the Factory Acceptance test

ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the clarification is an integral part of the document and has been incorporated in the tender proposal.

Signed

Date

Tenderer