



KENYA ELECTRICITY GENERATING COMPANY LIMITED

KGN-GDD-023-2018

TENDER FOR SUPPLY OF STEAM FLOW METERS FOR OLKARIA I POWER STATION

4th April, 2018.

CLARIFICATION NO. 1:

In accordance with the **Tender for Supply of Steam Flow Meters for Olkaria I Power Station**, KenGen hereby issues Clarification No. 1.

BIDDERS REQUEST	KENGEN RESPONSE
Provide the following information to aid in submitting the relevant steam flow meter: 1. Saturated steam flow rate? 2. Pressure? 3. Temperature?	1. Saturated steam flow rate? – 150 t/h 2. Pressure? – 6 bar g 1. 3. Temperature? – 158.8 °C

ACKNOWLEDGEMENT OF CLARIFICATION NO.1

We, the undersigned hereby certify that the clarification is an integral part of the document and has been incorporated in the tender proposal.

Signed

Tenderer