



KENYA ELECTRICITY GENERATING COMPANY LIMITED

TENDER NO. KGN-GDD-063-2018

DATE: 31/05/2018

TENDER FOR SUPPLY OF ASSORTED ELECTRICAL AND MECHANICAL EQUIPMENT FOR
OLKARIA WELLHEAD POWER PLANTS

*(Multi-Process Welding Machine complete with a Generator, Trailer Mounted
Rotary Screw Compressor, Diesel Generators, Skid Mounted Portable Centrifuges and
Rotary Screw Compressors)*

CLARIFICATION NO.1:

In accordance with the tender mentioned above, KenGen hereby issues Clarification No. 1:

No	Bidders Question	KenGen' Response
1	<p>In the above mentioned tender document under TECHNICAL SPECIFICATIONS for SCHEDULE C (DIESEL GENERATORS) it states</p> <p>"This specification covers the supply, testing, and commissioning of two brand new tropicalized canopied 3-phase, 4-wire, 415/240 Volt, 50 Hz, 250 kVA Standby and 500kVA Prime automatic diesel generating sets...."</p> <p>(Which, according to me, means 2 different generators)</p> <p>BUT, under the SCHEDULE OF REQUIREMENTS and PRICE SCHEDULE it only mentions the 250kVA generator set</p> <p>Please clarify</p>	<p>One type/rating of generator is required, 250 kVA Standby rating. 2 generator sets are required in the price schedule. All generators must meet the technical specifications as set out in the tender document.</p>

NOTE:

Particulars of appendix to instructions to tenders and evaluation criteria as issued in the original tender document remain unchanged.

TENDERER'S NAME: _____

TENDERER'S SIGNATURE & STAMP: _____

ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned hereby certify that the Clarification is an integral part of the document and has been incorporated in the tender document.

Signed

Tenderer:

Date