



**KENYA ELECTRICITY GENERATING COMPANY LIMITED**

**TENDER NO. KGN-GDD-070-2018**

**DATE: 8/06/2018**

**TENDER FOR STRUCTURAL REHABILITATION OF OLKARIA II GEOTHERMAL POWER STATION**

**CLARIFICATION NO.1:**

In accordance with the tender mentioned above, KenGen hereby issues Clarification No. 1:

No	Bidders Question	KenGen' Response
1.	Clarify on the items given below.  ELEMENT-3  Page No- 143/144  Item No- 3.01,3.03 & 3.04  Description - Square Hollow sections 250mm x 250mm x12mm  This materials are not available locally, can we give equivalent to this size and weight/linear meter	This is a rehabilitation project and the steel sections have got to match with the existing ones, bidders are free to source materials from anywhere in the world as long as they do not deviate from our specifications

**ACKNOWLEDGEMENT OF CLARIFICATION NO. 1**

We, the undersigned hereby certify that the Clarification is an integral part of the document and has been incorporated in the tender document.

Signed .....

Tenderer: .....

Date: .....

