



KENYA ELECTRICITY GENERATING COMPANY LIMITED

KGN-GDD-096-2017

TENDER FOR PROCUREMENT OF 120MM² CABLE FOR SUPPLY OF OLKARIA 1 POWER STATION COOLING TOWER MOTORS

CLARIFICATION 1

Date: 5th January 2018

In accordance with the *TENDER FOR PROCUREMENT OF 120MM² CABLE FOR SUPPLY OF OLKARIA 1 POWER STATION COOLING TOWER MOTORS*

KenGen hereby issues Clarification no. 1

CLARIFICATION NO. 1

No.	BIDDER'S QUESTION	KENGEN'S RESPONSE
1.	Clarify if the conductor is soft tinned wire	The conductor shall be stranded tinned copper which is normally described as Class 2 in IEC 60228 standard
2.	Clarify if the conductor is Class 5 or Class 6	

ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned hereby certify that clarification is an integral part of the document and the alternations set out in the clarification have been incorporated in the tender proposal.

Signed

Tenderer.....