

KENYA ELECTRICITY GENERATING COMPANY

13th March 2017

**TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF
200AH BATTERIES AND ASSOCIATED BATTERY CHARGER FOR GAS TURBINE
/NGONG POWER PLANTS: KGN- GT-04-2017.**

KenGen wishes to issue the following additional information on the tender in question through Addendum 1:

No	Issue of clarification	Actual changes / clarification
1	Extension of tender closure	Tender closing date has been extended from 23rd March 2017 to 3rd April 2017 at 2.00pm
2	Site visit requirement	Site visit is mandatory at Ngong Wind Plant. Bidders are advised to visit the site any time during official working hours before tender closure. Evidence of site visit will be a mandatory requirement at preliminary level of tender evaluation. Pre-bid site visit at Ngong Wind Plant shall be mandatory to appreciate the existing battery rack, the charger location and the interconnecting cable between the battery charger and battery bank and ambient operating environment among other conditions
3	Location of the battery and the charger.	The batteries together with the associated battery charger will be installed at Ngong Wind Plant station. Pre-bid visit to appreciate a minimum of the following: a) Battery rack size, condition and suitability for accommodating the new batteries (Bidders expected to use existing battery rack. If not suitable, the supplier to cost new rack and include in the tender. In case of new rack, it shall be located where the existing one is located) b) Location of the Battery Charger c) Size and length of the cable between battery bank and battery charger. Bidder to supply cable of similar size or larger depending on design to assure optimum performance of the installation d) Battery cable clamps to be similar to existing or better make and larger size

ACKNOWLEDGEMENT OF ADDENDUM NO.1

We, the undersigned hereby certify that the clarification is an integral part of the document and has been incorporated in the tender proposal.

Signed

Date

Tenderer