

KENYA ELECTRICITY GENERATION COMPANY

14th March 2017

TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 200AH BATTERIES AND ASSOCIATED BATTERY CHARGER FOR GAS TURBINES/NGONG POWER PLANTS :(KGN-GT-04-2017)

KenGen wishes to make the following clarification through addendum Number 2

No	Issue of clarification	KenGen Position
1	Batteries type	Maintenance type only (flooded type batteries)
2	Hydrometer details	Digital battery hydrometer and tester
3	Technical specifications of the Hydrometer	<p>±0.002 Measurement accuracy- Specific gravity: 1.000 to 1.300 (available to 1.400)</p> <p>Temperature: 41 to 104° F (5 to 40° C)</p> <p>LED display- specific gravity, temperature and count</p> <p>IP64 water resistant</p> <p>Specific gravity of sulfuric acid temp. compensated to 77° F (25° C)</p> <p>Temperature of sulfuric acid as electrolyte in lead-acid batteries</p> <p>Method of Detection- Light refraction system</p> <p>Size and weight-light enough to be hand held</p> <p>Suction Nozzle-9.5" L x 1/8" dia. flexible silicone tube</p> <p>Power Supply-9V alkaline battery</p> <p>Other Accessory-</p> <p>carry case</p> <p>Spare silicon tubes</p> <p>Instruction Manual</p>

ACKNOWLEDGEMENT OF ADDENDUM NO.2

We, the undersigned hereby certify that the clarification is an integral part of the document and has been incorporated in the tender proposal.

SignedDate

.....
Tenderer