



TENDER NO. KGN-HYD (tana) -01-2017

DATE: 17/02/2017

KENYA ELECTRICITY GENERATING COMPANY

TENDER FOR SUPPLY OF HIGH VOLTAGE STATOR COILS FOR 3.3kV, 625 KVA GENERATOR

CLARIFICATION No .2

In accordance with the **Tender for Supply of High Voltage Stator Coils for 3.3kV, 625 KVA Generator**, KenGen hereby issues Clarification No.2

RESPONSE TO REQUEST FOR CLARIFICATION

Clarification

1. Please send us photographs of **Herring bone tape** which is mentioned in Rewinding material list as (item No. 1 & 2)
2. mention thickness of the tape - **Herring bone tapes come in 12mm and 25mm**



Figure 1 HERRING BONE TAPE

3. Send photographs of 12 mm systoflex sleeves (item no. 13).



Figure 2 SYSTOFLEX SLEEVES

4. You have mentioned Soft epoxy mica tape in (item no. 3) we would like to know where this tape will be used? **Mica tape is used for taping end joints**
5. Please send photographs of Soft epoxy mica tape



Figure 3 SOFT EPOXY MICA TAPE

All other terms and conditions remain unchanged

ACKNOWLEDGEMENT OF CLARIFICATION NO. 2

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in the Addendum have been incorporated in the tender proposal.

Signed.....

Tenderer.....

