



TENDER NO. KGN-HYD (tana) -01-2017

DATE: 15/03/2017

KENYA ELECTRICITY GENERATING COMPANY

TENDER FOR SUPPLY OF HIGH VOLTAGE STATOR COILS FOR 3.3kV, 625 KVA GENERATOR

CLARIFICATION No .4

In accordance with the Tender for Supply of High Voltage Stator Coils for 3.3kV, 625 KVA Generator, KenGen hereby issues Clarification No.3

RESPONSE TO REQUEST FOR CLARIFICATION

	CLARIFICATION	KenGen RESPONSE
1.	In main tender document you are requesting for 216coils but slots are only 108 as the machine should only need 108 coils. You have stated that you want 54 spare coils which is fine but still does not explain why you require 216 coils, Do you require 2 complete sets and also 54 spare? Kindly advice.	The requirement is 216 coils (2 sets of 108 coils and an extra 54 coils as spares)
2.	Can you kindly send us a photo of the winding overhang showing “Mouth of slot blocks”, Mouth of slot binding cord” and “Top and bottom overhang packers”. Items 14, 15 and 16 in main tender doc	These details shall be provided to the winning bidder if necessary
3.	From main tender doc, kindly advise what you mean by 'graphite impregnated' in items 6 & 7?	Graphite coated instead of impregnated

All other terms and conditions remain unchanged

ACKNOWLEDGEMENT OF CLARIFICATION NO. 4

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in the Addendum have been incorporated in the tender proposal.

Signed.....

Tenderer.....

