



TENDER NO. KGN-HYD-021-2017

DATE: 2/08/2017

KENYA ELECTRICITY GENERATING COMPANY

TENDER FOR ROBOTIC UNDERWATER TAILRACE TUNNEL INSPECTION IN KAMBURU, GITARU AND KIAMBERE POWER STATIONS

CLARIFICATION No .1

Tender for Robotic Underwater Tailrace Tunnel Inspection in Kamburu, Gitaru and Kiambere Power Stations, KenGen hereby issues Clarification No.1

RESPONSE TO REQUEST FOR CLARIFICATION

	CLARIFICATION	KenGen RESPONSE
1.	Kindly Provide Pictures of areas where the inspection equipment and electronics may be setup along with any showing the relation of this area to the area where the vehicle would access the tunnel? For example, are there elevation changes between these areas? Long distance? Confined areas?	Power supply to the surge tunnels will be drawn from the powerhouse for the case of Kamburu and Gitaru while there is power supply at Kiambere draft tube gallery. The surge tunnels slope towards the tailrace tunnel as shown in the drawings sent earlier. <i>(Photographs have been uploaded separately as 'SURGE TUNNEL KAMBURU, GITARU AND KIAMBERE ').</i>

All other terms and conditions remain unchanged.

ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in the Addendum have been incorporated in the tender proposal.

Signed.....

Tenderer.....