



KENYA ELECTRICITY GENERATING COMPANY LIMITED

KGN-HYD-029-2016. TENDER FOR DESIGN, SUPPLY, INSTALLATION, TEST AND COMMISSIONING OF DELUGE FIRE PROTECTION SYSTEMS FOR GENERATOR TRANSFORMERS AND STATION TRANSFORMERS IN 7 FORKS POWER STATIONS.

21st Nov ~~y~~, 2016.

ADDENDUM NO. 1

In accordance with tender for design, supply, installation, test and commissioning of deluge fire protection systems for generator transformers and station transformers in 7 forks power stations, KenGen wishes to issue addendum no.1

1	Tender closing & Opening date	The new tender closing date shall be 5th Jan 2017 at 2.00pm and opening on the same day at 2.30pm at the same venue in the presence of the bidders who may wish to attend the opening.
2	Opening of roads for pipe-works and cables	Where the tenderer has to open up the road to pave way for laying pipe-works, power cables and signal cables etc, the contractor will undertake to make good such roads to previous state after laying of the pipes and cables.

3	Pipes and cables trenching	Pipes and cables shall be buried in trenches unless otherwise stated. The trench shall be 2 feet deep and shall be backfilled after laying of the pipes & cables
4	Pump houses	New pump houses shall be built to accommodate the new pumps for the project at Gitaru Power Station as the existing pump house is already squeezed. It shall be of similar design to the pump houses for Masinga and Kindaruma. The cost of such construction shall be indicated in the BOQ (Bill of Quantities) for the respective station and priced. The pump houses shall be of similar design to the existing pump houses in the respective stations.
5	Supply cables, Control cables and associated cable trays and trenches	The Power supply cables, signal cables, Power connection accessories, Cable trays, trenches where necessary, for such cables are in the scope of the supply under this tender. KenGen will show the point from which such power shall be tapped within the Control room and 415 Ac boards + DC supply source. The contractor will be responsible for supply of all accessories for such works including the Protection breakers
6	Section G- Bill of Quantities/Price schedule. Clause (1.2 pg. 84), (1.3 pg. 86), (1.4 pg. 87), (1.5 pg. 90), 1.6 pg. 92	Every <i>lot</i> in the BOQ/Price schedule for each station shall have a separate attachment showing the itemized components. This shall include description of the item, number, Unit price and total cost per line item. This shall individually priced and the total price transferred to the lot in the price schedule (BOQ). <i>Any bidder who does not show this itemized individual price per item per lot shall have his bid considered none responsive.</i>

ACKNOWLEDGEMENT OF ADDENDUM NO. 1

We, the undersigned hereby certify that the addendum is an integral part of the document and has been incorporated in the tender.

Document.

Signed

Tenderer:

Date