



KenGen

TENDER NO. KGN-TURK-05-2017

DATE: 6/04/2017

KENYA ELECTRICITY GENERATING COMPANY

TENDER FOR SUPPLY, INSTALLATION TEST AND COMMISSIONING OF INDUSTRIAL BATTERY CHARGER AND BATTERY BANK FOR TURKWEL POWER STATION

CLARIFICATION No .1

In accordance with the Tender for Supply, Installation Test and Commissioning of Industrial Battery Charger and Battery Bank for Turkwel Power Station, KenGen hereby issues Clarification No.1

RESPONSE TO REQUEST FOR CLARIFICATION

	CLARIFICATION	KenGen RESPONSE
1	Please note that in Technical specification Clause No.5.10.2.3-d-Charger Rating mentioned as 110V/60A. We understand that Charger Rating-110v/60A to be offered. Kindly confirm.	As per tender clause 5.10.2.3(d) Output current is 60A
2	We understand that DCDB to offer as per Technical Specification-Clause No.1.5.10.2.6-Integral DCDB. Please confirm.	Please quote as per tender specification of the clause 1.5.10.2.6
3	Please note that in Technical specification Clause No.5.10.3.4-Charger Rating mentioned as 48V/60A. We understand that Charger Rating-48v/60A to be offered. Kindly confirm.	As per tender clause 5.10.3.4(d) Output current is 60A
4	Technical Specification Clause No.5.10.3.15-%Effciency-80%. Please note that %Efficiency for 48V will be 70% at Maximum output voltage and current.	Tender specifications clause 5.10.3.15 requires <u>minimum</u> charger efficiency of 80% and NOT 70%.

All other terms and conditions remain unchanged

ACKNOWLEDGEMENT OF CLARIFICATION NO. 1

We, the undersigned hereby certify that the addendum is an integral part of the document and the alterations set out in the Addendum have been incorporated in the tender proposal.

Signed.....

Tenderer.....