


THIS DRAWING IS THE COPYRIGHT OF THE ENGINEER ANY REPRODUCTION OR USE OF THE DRAWING FOR CONSTRUCTION WITHOUT WRITTEN CONSENT FROM ENGINEER IS ILLEGAL.

GENERAL

1. The exact depth of excavation to be determine on site
2. All pipes shall be pressure tested before filling/concreting on ground.
3. All pipes crossing the roads shall be haunch with concrete class 25/20mm.
4. All road crossing and fittings in chamber to be galvanized mild steel or equivalent.
5. All pipes shall be galvanized iron(GI) class B.



DATE	DESCRIPTION
	Proposed construction of Elevated Water tanks.
	Raw Water pipes Laying from Office Block to .
	Base-Camp in Sondu Meru Power Station .

KenGen
P.O. BOX NAIROBI
PROPOSED DEVELOPMENT KenGen PLOT
SONDU MERU POWER STATION

DRG. TITLE
TYPICAL PLAN OF BASE-CAMP External Works.
RAW WATER SUPPLY LAYOUT.

	JOB No.2/4
	DRG No.002
	2DND FILE
DRAWN BY COLLINS.	SCALES AS SHOWN
CHECKED BY SD.	DATE: 18th December 2017